

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230487

Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064
2740 NE HAGAN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Punch List Inspection	Nick Scott	Partial	Thursday, September 12, 2024

Corrective Action Required:

- | | | | |
|---|---------------|----|--|
| 1 | Miscellaneous | 1) | Fix curbs joint to joint where marked |
| | Correction | 2) | Fix sidewalk joint to joint where marked |
| | | 3) | Fix approach to ADA ramps |
| | | 4) | Removed 2x4's from under lid and replace with concrete |
| | | 5) | Grout inside of storm inlets and throats |

Comments: