

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240374
Address: 3225 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, September 12, 2024

Corrective Action Required:

1	Misc	-furr around hvac in garage and fire block-PAN OFF TOP OF CHASE -complete furr down in great room and fire block-FIREBLOCK TOP OF CHASE LEFT SIDE
---	------	--

Comments: