

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236587
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, September 12, 2024

Corrective Action Required:

1	Misc	-Support lvl beams above deck at building ends. Have engineer take a look at this again.
---	------	------------------------------------------------------------------------------------------

****DO NOT ROCK THE EXTERIOR WALL WHERE THE DECK LVL BEAMS ARE SUPPORTED, UNTIL THE BEAM SUPPORT ISSUE ABOVE IS RESOLVED**

Comments: