

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235208  
Address: 2911 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, September 12, 2024

Informational:  
1 Misc

Ok below:

- Front foundation wall from A to L.5; east stair f.wall
- Completion of storm shelter foundation wall
- Slab above storm shelter-OK to pour pending approval from engineer

**Comments:**