

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234924  
Address: 2782 SW 12TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Ready for Temp CO	Friday, September 13, 2024

Corrective Action Required:

1	Misc	- Final grading and sod - Provide splash pads , divert water 36" away from foundation - sump discharge to be 36" away from foundation
---	------	---

**Comments:**