

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241491
Address: 4005 NE APPLE GROVE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Friday, September 13, 2024

Corrective Action Required:

1	Misc	-Connect the ufer grounding conductor to the middle service grounded bus bar; or install a #4 copper jumper from the EGC grounding bus bar to the middle grounded bus bar -Properly connect conductor to grounding rod
---	------	---

Comments: