## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20241491

Address: 4005 NE APPLE GROVE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection Khanh Nguyen Failed Friday, September 13,

2024

Corrective Action Required:

1 Misc -Connect the ufer grounding conductor to the middle service grounded bus

bar; or install a #4 copper jumper from the EGC grounding bus bar to the

middle grounded bus bar

-Properly connect conductor to grounding rod

**Comments:**