

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244348
Address: 2317 SW MORRIS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|------------------|----------|----------------------------|
| Sewer Service Inspection - R | Mitchell Schwarz | Failed | Monday, September 16, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Clean out required every 100' |
| | | Okay to cover where not installing clean out. |

Comments: