

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236080
Address: 2354 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, September 16, 2024

Corrective Action Required:

1	Misc	09/16/24- GB bracing screw pattern to be to code and plans 7"OC on edges and field
		-will check gb bracing when completed with drywall do not mud and tape gb bracing areas
		Okay to insulate

Comments: