

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234141  
Address: 400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                              | Inspector:       | Outcome: | Date:                      |
|--|------------------|----------|----------------------------|
| <b>All Rough Inspection - Commercial</b> | Mitchell Schwarz | Failed   | Monday, September 16, 2024 |

Corrective Action Required:

1 Misc

-Provide connection detail for I joists to top plate (fasten to engineer letter specifications, provide ladder on site to check)

Okay to cover walls

**Comments:**