

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20222424
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Dustin Agcopra	Passed	Monday, September 16, 2024

Informational:

1	Misc	8-19-24 BR Contractor preformed test on MH A-3 to MH A-4 failed Contractor preformed test on MH A-4 to MH A-5 pass..
		8-23-24 Dustin A, mandrel tests on A8-A7,A9-A8,A8-D1,A9-A10,A9-E1,A10-F1,A13-A12,A12-G1,A12-A11,A11-A10 Passed
		8-26-24 Dustin A, mandrel A3-A2 / Passed

Comments: