

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20222424  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Mandrel</b>	Dustin Agcopra	Partial	Monday, August 26, 2024

Informational:

1 Misc

8-19-24 BR Contractor preformed test on MH A-3 to MH A-4 failed  
Contractor preformed test on MH A-4 to MH A-5 pass..

8-23-24 Dustin A, mandrel tests on  
A8-A7,A9-A8,A8-D1,A9-A10,A9-E1,A10-F1,A13-A12,A12-G1,A12-A11,A11-A10  
Passed

8-26-24 Dustin A, mandrel A3-A2 / Passed

**Comments:**