

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236029

Address: 827 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
829 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
64064825 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, August 30, 2024

Corrective Action Required:

1 Misc

825:

-Roof ventilation cannot be within 4 ft of firewall **Cover the damaged area with FlameBlock board

827:

829:

-Engineer to address repair for damaged truss above master closet, master bed, and garage. Check throughout

Comments: