

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236029

Address: 827 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
829 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
64064825 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, September 17, 2024

Corrective Action Required:

1	Misc	825, 827: OK to rock
---	------	----------------------

829:

-Engineer to address repair for damaged truss above master bed

\*\*Engineer repair requires 2x4 scab on each face of the truss

**Comments:**