

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240682
Address: 3224 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, September 17, 2024

Corrective Action Required:

1	Misc	-address to be of contrasting colors -pay all fees -address pending pier inspection -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -all non gfci outlets in unfinished spaces to be single pull receptacle -complete primary bath plumbing -window fall protection for 2nd floor bedroom -seal all exterior penetrations -complete exterior fireplace
---	------	---

Comments: