

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236605
Address: 3832 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Tuesday, September 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	Sod to siding in the backyard on the West side of the porch does not have the required 4 inch minimum height clearance
---	--------------------------	--

(No improvements have been made since last inspection. WALK YOUR PROPERTY before scheduling inspections)

Pay \$125 in fees associated with this permit

Comments: