

September 4, 2024

Tom Garrison
Automated Control Systems
5251 W 116th Place, Suite 200
Leawood, KS 66211
913-248-8828 *office*

**RE: LEE'S SUMMIT CITY HALL RTU CHANGE OUT
LEE'S SUMMIT, MO**

JOB #2024-1745

Dear Mr. Garrison:

This letter is regarding the replacement of 5 RTUs on the roof of the above referenced building. It is my understanding that the new units are the same size as the old units and will fit on the existing curbs. Information on the new units that will be installed was provided. The original structural drawings that were dated 2004 and produced by Malter P Moore were also provided for my review.

I have reviewed the information provided and it is my opinion that the existing construction and roof curbs will adequately support the new replacement mechanical units. Please let me know if you have any questions or concerns, or if I can be of further help.

Sincerely,



Garth L. Durre, P.E.
Principal

