



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113001, Building Permit - Commercial
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Failed	Wednesday, October 12, 2011

Corrective Action Required
1 MISC

SUPPORT MC OVER STAIRS, AT 2HR WALL ABOVE DOOR
OPENING SOUTH SIDE.
APPROVED TO COVER SOUTHEAST ROOM.
DO NOT COVER SOUTH WEST ROOM / PENDING GAS LINE
APPROVAL AND FIRE PENETRATION.

DO NOT COVER UNTILL FIRE PENETRATIONS ARE INSPECTED
AND APPROVED.
RETURN AIR SHOWN ON PLANS TO ENTRY ROOM

Comments: