

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240625
Address: 3726 SW CLAYTON PL, LEES SUMMIT, MO 640823728 SW CLAYTON PL, LEES SUMMIT, MO
640823730 SW CLAYTON PL, LEES SUMMIT, MO 640823722 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Wednesday, September 18, 2024

Corrective Action Required:
2 Miscellaneous Erosion control measures are missing at the front of the lot next to the street
Correction on both sides

Full erosion control measures must be maintained until CofO

Comments: