

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242186
Address: 3245 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, September 19, 2024

Corrective Action Required:

1	Misc	-lib bracing not installed to plans (missing in some areas, missing nails, cut, incorrect size)[above stairs] -address broken truss B10 -uncover covered rear patio and front porch framing
---	------	---

Comments: