

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241111
Address: 2086 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Thursday, September 19, 2024

Informational:
1 Misc 9-12-24 Dustin A, SW was formed and compacted and slopes were in compliance. Approved to pour
9-19-24 Dustin A, Sw has been poured to city specs and slopes are in compliance. Pass

Comments: