



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20243082	Date:	September 20, 2024
Project Title:	NICK THE GREEK	Applicant:	
Location:			
1020 NW PRYOR RD, Unit:C, LEES SUMMIT, MO 64081		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	A-2	KANSAS CITY, MO 64116	
Description:	NICK THE GREEK - TENANT FINISH	Primary: (913) 888-0647	
FOR QUICK SERVE RESTAURANT			
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Craig Hill**

**Released for Construction**

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**