

Fire Sprinkler Solutions, Inc.

1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5633

1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5633

ALL SAFE
6603D Royal Street
Pleasant Valley, MO. 64068
P:816-492-7202
F:816-492-7310
info@allsafe-firepro.com

TM FIELDHOUSE
1550 SE Hamben Road
Lee's Summit, MO 64081



CONTRACT NO.
CONTRACT WITH OWNER
DRAWN BY:

CHECKED BY:
VC
PLOTTED FOR:
APPROVAL
DOCUMENT DATE:
08-27-24
SHEET NUMBER:
1 OF 2

THE ENTIRE BUILDING WILL BE DESIGNED PER NFPA 13.

ALL WET SYSTEM MAIN PIPING TO BE SCHEDULE 10 WITH ROLLED GROOVED END, GROOVED FITTINGS AND WELDED OUTLETS.

ALL WET SYSTEM WELDED BRANCHLINE PIPING TO BE SCHEDULE 10 WITH ROLLED GROOVED END, GROOVED FITTINGS AND WELDED OUTLETS.

ALL WET SYSTEM THREADED PIPE TO BE SCHEDULE 40 (BLACK) WITH CAST IRON THREADED FITTINGS.

SYSTEMS IS TO CONFORM WITH REQUIREMENTS OF NFPA 13. VALVES ON CONNECTIONS TO WATER SUPPLIES, SECTIONAL CONTROL VALVES AND OTHER VALVES IN SUPPLY LINES TO SPRINKLER SYSTEMS SHALL BE KEPT IN THE OPEN POSITION (EXCEPT FOR OTHERS). IT IS THE USER'S RESPONSIBILITY TO PROTECT ACCORDING HEAT TO KEEP THE SPRINKLER SYSTEM FROM FREEZING.

ALL SECTIONS OF TAPPED PIPING SHALL HAVE AUXILIARY DRAINS WHERE REQUIRED.

ALL ELECTRICAL WIRING OF ALARM BELLS, LOW SWITCHES AND PULLER SWITCHES (IF REQUIRED) TO BE DONE BY OTHERS. THE SPRINKLER SYSTEM IS TO BE INSTALLED IN ACCORDANCE WITH NFPA 13, 2016 EDITION.


THE SPRINKLER SYSTEM IS TO BE TESTED IN ACCORDANCE WITH THE REQUIREMENTS OF NFPA 13. THE TESTS SHALL BE CONDUCTED BY OTHERS. SPRINKLERS WILL BE NOT BE CONTAINED IN CEILING TILES. HANGERS TO BE SPACED TO MEET NFPA REQUIREMENTS. RESINIC BACKING IS NOT REQUIRED.

ROOF: METAL DECK ON STEEL PURLINS AND BEAMS

GRANULAR, CONCENTRATE, VESTIBULE, OFFICES, RESTROOMS, CORRIDORS, ETC.)
PER NFPA 13, LIGHT HAZARD GROUP 1
(REDUCED AREA FOR USE OF OR SPRINKLERS WHERE APPLICABLE)
MINIMUM 225 S.F. SPRINKLER SPACING
100 GPM HOSE ALLOWANCE
COOKING, STORAGE ROOMS, MECHANICAL ROOMS:
PER NFPA 13, ORDINARY HAZARD GROUP 1
(REDUCED AREA FOR USE OF OR SPRINKLERS WHERE APPLICABLE)
MINIMUM 130 S.F. SPRINKLER SPACING
250 GPM HOSE ALLOWANCE

FLOW TEST:

STATIC: 82 PSI
 RESIDUAL: 56 PSI WITH 1980 GPM FLOWING
 LOCATION: Hydrant #047-057 FH
 SE KINGSPONT DRIVE - SOUTH OF HAMBLEN ROAD
 ELEVATION: APPROXIMATELY 10' BELOW FINISHED FLOOR
 DATE: 07-23-2024
 INFORMATION FROM: LEE'S SUMMIT WATER UTILITIES

[illegible]

FIRE SPRINKLER PLAN
(WEST)

HANGER SPACING TABLE											
PIPE SIZE (NOMINAL, INCHES)											
STEEL PIPE (EXCEPT THREADED LIGHTWALL)	N/A	1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"	6"	8"	
STEEL PIPE (THREADED LIGHTWALL)	N/A	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	N/A	N/A	
COPPER	N/A	8'-0"	8'-0"	10'-0"	10'-0"	12'-0"	12'-0"	15'-0"	15'-0"	15'-0"	
CPVC	5'-6"	6'-0"	6'-6"	7'-0"	8'-0"	9'-0"	10'-0"	N/A	N/A	N/A	

TYP. HANGER #01



NO SCALE

TYP. HANGER #05

NO SCALE

TYP. HANGER #01

NO SCALE




REVISIONS:	
#	DATE DESCRIPTION

Fire Sprinkler Solutions, Inc.
1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5633

 **ALL SAFE** FIRE PROTECTION LLC

6603D Royal Street
Pleasant Valley, MO. 64068
P:816-492-7202
F:816-492-7310
info@allsafe-firepro.com

TM FIELDHOUSE
1550 SE Hamben Road
Lee's Summit, MO 64081



CONTRACT NO.
CONTRACT WITH OWNER
DRAWN BY:

PCL

CHECKED BY:

VC


PLOTTED FOR:


APPROVAL

DOCUMENT DATE:

08-27-24

SHEET NUMBER.



TYPE	SOUL	TYPE	SOUL	TYPE	SOUL
 TYP HANGER #01 1/2"	 TYP HANGER #05 1/2"	 TYP HANGER #01 1/2"	 TYP HANGER #01 1/2"	 TYP HANGER #01 1/2"	 TYP HANGER #01 1/2"

PIPE SIZE (NOMINAL INCHES)	3/4"	1"	1-1/4"	1-1/2"	2"	3-1/2"	3"	4"	6"	8"
STEEL PIPE (CONCEPT THREADED JOINTWALL)	N/A	12'-0"	12'-0"	15'-0"	15'-0"	15'-0"	15'-0"	15'-0"	15'-0"	15'-0"
STEEL PIPE (THREADED JOINTWALL)	N/A	12'-0"	12'-0"	15'-0"	12'-0"	12'-0"	12'-0"	N/A	N/A	N/A
COPPER	8'-0"	10'-0"	10'-0"	12'-0"	12'-0"	12'-0"	12'-0"	15'-0"	15'-0"	15'-0"
CPVC	5'-6"	8'-0"	6'-6"	7'-0"	8'-0"	9'-0"	10'-0"	N/A	N/A	N/A

SYMBOL	DESCRIPTION
①	HYDRAULIC REFERENCE POINT
$(\sigma^{\circ}-\sigma^{\circ})$	CEILING HEIGHT
BOP	BOTTOM OF PURLIN ELEVATION ABOVE FINISHED FLOOR
$\left[\frac{1}{2} \sigma^{\circ}-\sigma^{\circ} \right]$	CENTRELINE OF PIPE DOWN FROM BOTTOM OF PURLIN
$\left[\frac{1}{2} \sigma^{\circ}-\sigma^{\circ} \right]$	CENTRELINE OF PIPE A.F.F.
RM	RISER INPLE
○ DN	PIPE DOWN
○	SPRINKLER RISER
→	APPROX TO THE VALVE ON PIPE

SPRINKLER LEGEND									
SYMBOL	SPRINKLER TYPE	SIN #	FINISH	TEMP.	THERMAD. K-FACTOR	ROOF/CILING	UNDER WETZ	TOTAL	
●	RELIABLE MODEL FTFR55 O.R. RECESSED PENDENT	RA1414	WHITE	155°	1/2"	5.6	39	17	56
○	RELIABLE MODEL FTFR55 O.R. UPRIGHT	BRASS	200°	1/2"	5.6	282	-	282	
①	RELIABLE MODEL FTFR55 O.R. UPRIGHT (ON SPRIG-UP)	RA1425	BRASS	200°	1/2"	5.6	8	6	14
●	RELIABLE MODEL TCR55 O.R. DRY PENDENT	RA2714	CHROME	200°	1/2"	5.6	2	-	2
			WHITE						
							311	23	334

Hydraulic Calculations

TM FIELDHOUSE

1550 SE Hamblen Road
Lee's Summit, MO 64081

Date: 08-27-24

Calculated by: Paul C. Link, P.E.

Area Summary:

Area	Description	GPM	PSI	Demand Location
Area #1	Gynnasium	303	58.9	at conn to city main
Area #2	Cooking / Serving	541	60.6	at conn to city main
Area #3	Under Mezzanine	476	62.5	at conn to city main



ALL SAFE FIRE PROTECTION LLC

6603D Royal Street
Pleasant Valley, MO. 64068
P:816-492-7202
F:816-492-7310
info@allsafefirepro.com

Fire Sprinkler Solutions, Inc.

1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 * fax: 816-468-5633

On 2024-07-24 8:06 am, Brandon Williams wrote:

Good Morning Vincent,


We performed the hydrant flow test for 1550 SE Hamblen Rd yesterday, 7/23/2024 at 11:00am.

Static Pressure: 82 PSI
Flow: 1980 GPM
Residual Pressure: 56 PSI

Yours Truly,

Brandon Williams | Operations Technician
1200 SE Hamblen Road | Lee's Summit, MO 64081
816.969.1970 | lswater.net | Brandon.Williams@cityofls.net





Hydraulic Design Information Sheet

Name - TM Fieldhouse area #1 Date - 08-27-24
Location - gymnasium
Building - TM Fieldhouse System No. - wet
Contractor - Allsafe Fire Protection Contract No. -
Calculated By - Paul C. Link, P.E. Drawing No. - 2 of 2
Construction: () Combustible (X) Non-Combustible Ceiling Height - 31'4
Occupancy - athletic club

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
M Area of Sprinkler Operation - 1500 System Type Sprinkler/Nozzle
Density - 0.10 (X) Wet Make Reliable
D Area Per Sprinkler - varies () Dry Model F1FR56
E Elevation at Highest Outlet - 30'11 () Deluge Size 1/2"
S Hose Allowance - Inside () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - () Other Temp.Rat.200
G Hose Allowance - Outside - 100

N Note

Calculation Flow Required - 303 Press Required - 58.9
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 07-23-2024 Cap. -
T Time of Test - Rated Cap.- Elev.-
E Static Press - 82 @ Press -
R Residual Press - 56 Elev. - Well
Flow - 1980 Proof Flow
S Elevation - -10'

U Location - hydrant #047-057 - SE Kingspoint Drive - south of Hamblen Road

P Source of Information - Lee's Summit Water Utilities

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S () Single Row () Conven. Pallet () Auto. Storage () Encap.
R () Double Row () Slave Pallet () Solid Shelf () Non
T A () Mult. Row () Open Shelf
O C

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

G Horizontal Barriers Provided:
E

Water Supply Curve C

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #1


Page 2
Date 08-27-24

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 56
C2 - Residual Flow : 1980

Demand:

D1 - Elevation : 17.722
D2 - System Flow : 203.283
D2 - System Pressure : 58.927
Hose (Demand) : 100
D3 - System Demand : 303.283
Safety Margin : 22.265



Fittings Used Summary

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #1

Page 3
Date 08-27-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #1

Page 4
Date 08-27-24

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TST	82.0	56	1980.0	81.192	303.28	58.927

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
101	30.92	5.6	8.69	16.51	
102	30.92	5.6	8.81	16.62	
103	30.92	5.6	9.24	17.03	
104	30.92	5.6	10.17	17.86	
105	30.92		18.12		
106	26.08		22.69		
206	30.17		26.8		
TOR	30.17		32.58		
BOR	0.0		48.12		
UG1	0.0		48.3	100.0	
UG2	0.0		49.23		
BFP	0.0		54.5		
TST	-10.0		58.93		
107	30.92	5.6	8.58	16.41	
108	30.92	5.6	8.7	16.52	
109	30.92	5.6	9.13	16.92	
110	30.92	5.6	10.05	17.75	
111	30.92		17.9		
112	26.08		22.44		
113	26.08		22.49		
114	30.92	5.6	8.6	16.43	
115	30.92	5.6	8.72	16.54	
116	30.92	5.6	9.15	16.94	
117	30.92	5.6	10.07	17.77	
118	30.92		17.94		

Final Calculations - Hazen-Williams - 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #1

Page 5
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
101 to 102	30.920 30.920	5.60	16.51 16.51	1.5 1.682	0.0 0.0	13.000 0.0	120 0.0092	8.692 0.119		Vel = 2.38	
102 to 103	30.920 30.920	5.60	16.62 33.13	1.5 1.682	0.0 0.0	13.000 0.0	120 0.0332	8.811 0.432		Vel = 4.78	
103 to 104	30.920 30.920	5.60	17.03 50.16	1.5 1.682	0.0 0.0	13.000 0.0	120 0.0715	9.243 0.930		Vel = 7.24	
104 to 105	30.920 30.920	5.60	17.86 68.02	1.5 1.682	2E 0.0	9.9 9.900	53.330 63.230	120 0.1257	10.173 7.946	Vel = 9.82	
105 to 106	30.920 26.080		0.0 68.02	1.5 1.682	E T 0.0	4.95 9.9 19.680	4.830 14.850	120 0.1257	18.119 2.096 2.474	Vel = 9.82	
106 to 206	26.080 30.170		135.26 203.28	3 3.26	2E 0.0	18.815 18.815	136.250 155.065	120 0.0380	22.689 -1.771 5.885	Vel = 7.81	
206 to TOR	30.170 30.170		0.0 203.28	3 3.26	2E T 0.0	18.815 20.159	113.330 38.974	120 0.0380	26.803 0.0 5.780	Vel = 7.81	
TOR to BOR	30.170 0		0.0 203.28	3 3.26	B S 0.0	13.44 21.503	30.170 34.943	120 0.0379	32.583 13.067 2.471	Vel = 7.81	
BOR to UG1	0 0		0.0 203.28	6 6.16	E T 0.0	20.084 43.037	75.000 63.121	140 0.0013	48.121 0.0 0.178	Vel = 2.19	
UG1 to UG2	0 0	H100	100.00 303.28	6 6.16	E 2T 0.0	20.084 86.075	240.000 106.159	140 0.0027	48.299 0.0 0.934	Vel = 3.26	
UG2 to BFP	0 0		0.0 303.28	8 8.27	2E 0.0	56.936 56.936	365.000 421.936	140 0.0006	49.233 5.000 0.271	** Fixed Loss = 5 Vel = 1.81	
BFP to TST	0 -10		0.0 303.28	8 8.27	2G T 0.0	12.652 55.354	75.000 68.006	140 0.0006	54.504 4.331 0.092	Vel = 1.81	
TST			0.0 303.28						58.927	K Factor = 39.51	
107 to 108	30.920 30.920	5.60	16.41 16.41	1.5 1.682	0.0 0.0	13.000 0.0	120 0.0091	8.583 0.118		Vel = 2.37	
108 to 109	30.920 30.920	5.60	16.51 32.92	1.5 1.682	0.0 0.0	13.000 0.0	120 0.0328	8.701 0.426		Vel = 4.75	
109 to 110	30.920 30.920	5.60	16.92 49.84	1.5 1.682	0.0 0.0	13.000 0.0	120 0.0707	9.127 0.919		Vel = 7.20	
110 to 111	30.920 30.920	5.60	17.75 67.59	1.5 1.682	2E 0.0	9.9 9.900	53.330 63.230	120 0.1242	10.046 0.0 7.855	Vel = 9.76	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #1

Page 6
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
111 to 112	30.920 26.080		0.0 67.59	1.5 1.682	E T 4.95 9.9 0.0	4.830 14.850 19.680	120 0.1242	17.901 2.096 2.445		Vel = 9.76	
112 to 113	26.080 26.080		0.0 67.59	3 3.26	0.0 0.0 0.0	9.250 0.0 9.250	120 0.0050	22.442 0.0 0.046		Vel = 2.60	
113 to 106	26.080 26.080		67.67 135.26	3 3.26	0.0 0.0 0.0	11.250 0.0 11.250	120 0.0179	22.488 0.0 0.201		Vel = 5.20	
106			0.0 135.26					22.689		K Factor = 28.40	
114 to 115	30.920 30.920	5.60	16.43 16.43	1.5 1.682	0.0 0.0 0.0	13.000 0.0 13.000	120 0.0091	8.603 0.0 0.118		Vel = 2.37	
115 to 116	30.920 30.920	5.60	16.53 32.96	1.5 1.682	0.0 0.0 0.0	13.000 0.0 13.000	120 0.0329	8.721 0.0 0.428		Vel = 4.76	
116 to 117	30.920 30.920	5.60	16.94 49.9	1.5 1.682	0.0 0.0 0.0	13.000 0.0 13.000	120 0.0708	9.149 0.0 0.921		Vel = 7.21	
117 to 118	30.920 30.920	5.60	17.77 67.67	1.5 1.682	2E 9.9 0.0 0.0	53.330 9.900 63.230	120 0.1245	10.070 0.0 7.871		Vel = 9.77	
118 to 113	30.920 26.080		0.0 67.67	1.5 1.682	E T 4.95 9.9 0.0	4.830 14.850 19.680	120 0.1245	17.941 2.096 2.451		Vel = 9.77	
113			0.0 67.67					22.488		K Factor = 14.27	

Hydraulic Design Information Sheet

Name - TM Fieldhouse area #2 Date - 08-27-24
Location - cooking / serving
Building - TM Fieldhouse System No. - wet
Contractor - Allsafe Fire Protection Contract No. -
Calculated By - Paul C. Link, P.E. Drawing No. - 2 of 2
Construction: () Combustible (X) Non-Combustible Ceiling Height - varies
Occupancy - athletic club

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
M Area of Sprinkler Operation - 900 System Type Sprinkler/Nozzle
Density - 0.10/0.15 (X) Wet Make Reliable
D Area Per Sprinkler - varies () Dry Model F1FR56
E Elevation at Highest Outlet - 10' () Deluge Size 1/2"
S Hose Allowance - Inside - () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - () Other Temp.Rat.155
G Hose Allowance - Outside - 100
N

Note cooking area is calculated at 0.15 gpm/sf - serving is 0.10 gpm/sf

Calculation Flow Required - 541 Press Required - 60.6
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 07-23-2024 Cap. -
T Time of Test - Rated Cap.- Elev.-
E Static Press - 82 @ Press -
R Residual Press - 56 Elev. - Well
Flow - 1980 Proof Flow
S Elevation - -10'

U Location - hydrant #047-057 - SE Kingspoint Drive - south of Hamblen Road

P Source of Information - Lee's Summit Water Utilities

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S R () Single Row () Conven. Pallet () Auto. Storage () Encap.
T A () Double Row () Slave Pallet () Solid Shelf () Non
O C () Mult. Row () Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

G Horizontal Barriers Provided:
E

Water Supply Curve C

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2


Page 2
Date 08-27-24

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 56
C2 - Residual Flow : 1980

Demand:

D1 - Elevation : 9.095
D2 - System Flow : 290.94
D2 - System Pressure : 60.590
Hose (Demand) : 250
D3 - System Demand : 540.94
Safety Margin : 19.053



Fittings Used Summary

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2

Page 3
Date 08-27-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2

Page 4
Date 08-27-24

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TST	82.0	56	1980.0	79.642	540.94	60.59

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
DP07	10.0	5.6	7.17	15.0	
EQ07	11.0		7.2		
DP06	10.0	5.6	14.08	21.01	
EQ06	11.0		13.79		
DP05	10.0	5.6	7.17	15.0	
EQ05	11.0		6.82		
DP01	10.0	5.6	9.51	17.27	
EQ01	11.0		9.38		
DP02	10.0	5.6	9.51	17.27	
EQ02	11.0		9.68		
DP04	10.0	5.6	7.2	15.02	
EQ04	11.0		7.22		
DP03	10.0	5.6	7.2	15.02	
EQ03	11.0		6.99		
201	11.0	5.66	13.79	21.01	K=K @ EQ06
202	11.0		15.45		
203	11.0		15.59		
204	11.0		15.98		
205	12.0		19.9		
206	30.17		18.05		
TOR	30.17		29.27		
BOR	0.0		47.13		
UG1	0.0		47.48	250.0	
UG2	0.0		50.2		
BFP	0.0		55.99		
TST	-10.0		60.59		
207	11.0	5.74	14.0	21.49	K=K @ EQ05
208	11.0		15.35		
209	11.0		15.3		
210	11.0		15.3		
211	11.0	5.64	12.84	20.21	K=K @ EQ01
212	11.0	5.55	13.05	20.06	K=K @ EQ02
213	11.0	5.59	13.63	20.63	K=K @ EQ07
214	11.0	5.66	14.26	21.37	K=K @ EQ06
215	11.0	5.64	13.4	20.64	K=K @ EQ01
216	11.0	5.55	13.61	20.49	K=K @ EQ02
217	11.0	5.64	13.52	20.74	K=K @ EQ01
218	11.0	5.55	13.81	20.63	K=K @ EQ02
219	11.0	5.64	13.61	20.81	K=K @ EQ01
220	11.0	5.55	13.83	20.65	K=K @ EQ02
221	11.0	5.68	13.9	21.18	K=K @ EQ03
222	11.0	5.59	14.13	21.01	K=K @ EQ04

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2

Page 5
Date 08-27-24

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
------------------------	-------------------------	-------------------------	------------------------------------	-------------------------------------	---------------------

Final Calculations - Hazen-Williams - 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2

Page 6
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP07 to EQ07	10 11	5.60	15.00 15.0	1 1.049	T 0.0 0.0	5.0 5.000 6.000	120 0.0763	7.175 -0.433 0.458		Vel = 5.57	
EQ07			0.0 15.00					7.200		K Factor = 5.59	
DP06 to EQ06	10 11	5.60	21.01 21.01	1 1.049	0.0 0.0 0.0	1.000 0.0 1.000	120 0.1420	14.076 -0.433 0.142		Vel = 7.80	
EQ06			0.0 21.01					13.785		K Factor = 5.66	
DP05 to EQ05	10 11	5.60	15.00 15.0	1 1.049	0.0 0.0 0.0	1.000 0.0 1.000	120 0.0760	7.175 -0.433 0.076		Vel = 5.57	
EQ05			0.0 15.00					6.818		K Factor = 5.74	
DP01 to EQ01	10 11	5.60	17.27 17.27	1 1.049	E 2.0 0.0 0.0	1.000 2.000 3.000	120 0.0993	9.513 -0.433 0.298		Vel = 6.41	
EQ01			0.0 17.27					9.378		K Factor = 5.64	
DP02 to EQ02	10 11	5.60	17.27 17.27	1 1.049	T 5.0 0.0 0.0	1.000 5.000 6.000	120 0.0993	9.513 -0.433 0.596		Vel = 6.41	
EQ02			0.0 17.27					9.676		K Factor = 5.55	
DP04 to EQ04	10 11	5.60	15.02 15.02	1 1.049	T 5.0 0.0 0.0	1.000 5.000 6.000	120 0.0767	7.196 -0.433 0.460		Vel = 5.58	
EQ04			0.0 15.02					7.223		K Factor = 5.59	
DP03 to EQ03	10 11	5.60	15.02 15.02	1 1.049	E 2.0 0.0 0.0	1.000 2.000 3.000	120 0.0767	7.196 -0.433 0.230		Vel = 5.58	
EQ03			0.0 15.02					6.993		K Factor = 5.68	
201 to 202	11 11	5.66	21.01 21.01	1 1.049	E T 2.0 5.0 0.0	4.670 7.000 11.670	120 0.1426	13.785 0.0 1.664		K = K @ EQ06 Vel = 7.80	
202 to 203	11 11		146.19 167.2	3 3.26	0.0 0.0 0.0	5.250 0.0 5.250	120 0.0265	15.449 0.0 0.139		Vel = 6.43	
203 to 204	11 11		41.46 208.66	3 3.26	0.0 0.0 0.0	9.750 0.0 9.750	120 0.0398	15.588 0.0 0.388		Vel = 8.02	
204 to 205	11 12		82.28 290.94	3 3.26	2E T 18.815 20.159 0.0	20.170 38.974 59.144	120 0.0737	15.976 -0.433 4.357		Vel = 11.18	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2

Page 7
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
205 to 206	12 30.170		0.0 290.94	3 3.26	2E T 20.159	18.815 38.974 81.644	120 0.0737	19.900 -7.869 6.015		Vel = 11.18	
206 to TOR	30.170 30.170		0.0 290.94	3 3.26	2E T 20.159	113.330 38.974 152.304	120 0.0737	18.046 0.0 11.221		Vel = 11.18	
TOR to BOR	30.170 0		0.0 290.94	3 3.26	B S 21.503	13.44 30.170 34.943	120 0.0737	29.267 13.067 4.797		Vel = 11.18	
BOR to UG1	0 0		0.0 290.94	6 6.16	E T 43.037	20.084 75.000 63.121	140 0.0025	47.131 0.0 0.345		Vel = 3.13	
UG1 to UG2	0 0	H250	250.00 540.94	6 6.16	E 2T 86.075	20.084 240.000 106.159	140 0.0079	47.476 0.0 2.724		Vel = 5.82	
UG2 to BFP	0 0		0.0 540.94	8 8.27	2E 2G T 55.354	56.936 365.000 56.936 421.936	140 0.0019	50.200 5.000 0.790	* * Fixed Loss = 5	Vel = 3.23	
BFP to TST	0 -10		0.0 540.94	8 8.27	2G T 55.354	12.652 75.000 68.006	140 0.0019	55.990 4.331 0.269		Vel = 3.23	
TST			0.0 540.94					60.590		K Factor = 69.49	
207 to 202	11 11	5.74	21.49 21.49	1 1.049	E T 5.0	2.750 7.000 9.750	120 0.1487	13.999 0.0 1.450		K = K @ EQ05	Vel = 7.98
202 to 208	11 11		-146.19 -124.7	3 3.26		0.0 6.750 0.0	120 -0.0154	15.449 0.0 -0.104		Vel = 4.79	
208 to 209	11 11		41.13 -83.57	3 3.26		0.0 6.000 0.0	120 -0.0073	15.345 0.0 -0.044		Vel = 3.21	
209 to 210	11 11		42.20 -41.37	3 3.26		0.0 2.000 0.0	120 -0.0020	15.301 0.0 -0.004		Vel = 1.59	
210			0.0 -41.37					15.297		K Factor = -10.58	
211 to 212	11 11	5.64	20.21 20.21	1.25 1.38		0.0 6.000 0.0	120 0.0348	12.844 0.0 0.209		K = K @ EQ01	Vel = 4.34
212 to 213	11 11	5.55	20.07 40.28	1.25 1.38		0.0 4.580 0.0	120 0.1251	13.053 0.0 0.573		K = K @ EQ02	Vel = 8.64
213 to 204	11 11	5.59	20.63 60.91	1.25 1.38	T 6.0	2.750 6.000 8.750	120 0.2686	13.626 0.0 2.350		K = K @ EQ07	Vel = 13.07
204			0.0 60.91					15.976		K Factor = 15.24	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #2

Page 8
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
214 to 204	11 11	5.66	21.37 21.37 0.0	1 1.049	E T 2.0 5.0 0.0	4.670 7.000 11.670	120 0.1470	14.260 0.0 1.716	K = K @ EQ06 Vel = 7.93		
204			21.37					15.976	K Factor = 5.35		
215 to 216	11 11	5.64	20.64 20.64	1.25 1.38	0.0 0.0 0.0	6.000 0.0 6.000	120 0.0362	13.396 0.0 0.217	K = K @ EQ01 Vel = 4.43		
216 to 208	11 11	5.55	20.49 41.13 0.0	1.25 1.38	T 6.0 0.0 0.0	7.330 6.000 13.330	120 0.1299	13.613 0.0 1.732	K = K @ EQ02 Vel = 8.82		
208			41.13					15.345	K Factor = 10.50		
217 to 218	11 11	5.64	20.74 20.74	1.25 1.38	0.0 0.0 0.0	8.000 0.0 8.000	120 0.0365	13.517 0.0 0.292	K = K @ EQ01 Vel = 4.45		
218 to 210	11 11	5.55	20.63 41.37 0.0	1.25 1.38	T 6.0 0.0 0.0	5.330 6.000 11.330	120 0.1313	13.809 0.0 1.488	K = K @ EQ02 Vel = 8.87		
210			41.37					15.297	K Factor = 10.58		
219 to 220	11 11	5.64	20.81 20.81	1.25 1.38	0.0 0.0 0.0	6.000 0.0 6.000	120 0.0368	13.609 0.0 0.221	K = K @ EQ01 Vel = 4.46		
220 to 203	11 11	5.55	20.65 41.46 0.0	1.25 1.38	T 6.0 0.0 0.0	7.330 6.000 13.330	120 0.1319	13.830 0.0 1.758	K = K @ EQ02 Vel = 8.89		
203			41.46					15.588	K Factor = 10.50		
221 to 222	11 11	5.68	21.18 21.18	1.25 1.38	0.0 0.0 0.0	6.000 0.0 6.000	120 0.0380	13.904 0.0 0.228	K = K @ EQ03 Vel = 4.54		
222 to 209	11 11	5.59	21.02 42.2 0.0	1.25 1.38	T 6.0 0.0 0.0	2.580 6.000 8.580	120 0.1362	14.132 0.0 1.169	K = K @ EQ04 Vel = 9.05		
209			42.20					15.301	K Factor = 10.79		

Hydraulic Design Information Sheet

Name - TM Fieldhouse area #3 Date - 08-27-24
Location - under mezzanine area
Building - TM Fieldhouse System No. - wet
Contractor - Allsafe Fire Protection Contract No. -
Calculated By - Paul C. Link, P.E. Drawing No. - 1 of 2
Construction: () Combustible (X) Non-Combustible Ceiling Height - 8'6
Occupancy - athletic club

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
M Area of Sprinkler Operation - 900 System Type Sprinkler/Nozzle
Density - 0.10/0.15 (X) Wet Make Reliable
D Area Per Sprinkler - varies () Dry Model F1FR56
E Elevation at Highest Outlet - 10'6 () Deluge Size 1/2"
S Hose Allowance - Inside - () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - () Other Temp.Rat.155
G Hose Allowance - Outside - 100
N

Note sprinklers in storage room calculated at 0.15 gpm/sf

Calculation Flow Required - 476 Press Required - 62.5
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 07-23-2024 Cap. -
T Time of Test - Rated Cap.- Elev.-
E Static Press - 82 @ Press -
R Residual Press - 56 Elev. - Well
Flow - 1980 Proof Flow
S Elevation - -10'

U Location - hydrant #047-057 - SE Kingspoint Drive - south of Hamblen Road

P Source of Information - Lee's Summit Water Utilities

L
Y
C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S () Single Row () Conven. Pallet () Auto. Storage () Encap.
R () Double Row () Slave Pallet () Solid Shelf () Non
T A () Mult. Row () Open Shelf
O C

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

G Horizontal Barriers Provided:
E

Water Supply Curve C

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #3


Page 2
Date 08-27-24

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 56
C2 - Residual Flow : 1980

Demand:

D1 - Elevation : 8.445
D2 - System Flow : 226.284
D2 - System Pressure : 62.605
Hose (Demand) : 250
D3 - System Demand : 476.284
Safety Margin : 17.532



Fittings Used Summary

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #3

Page 3
Date 08-27-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #3

Page 4
Date 08-27-24

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TST	82.0	56	1980.0	80.137	476.28	62.605

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
DP02	8.5	5.6	7.18	15.01	
EQ02	9.5		6.83		
DP01	8.5	5.6	7.18	15.01	
EQ01	9.5		7.21		
DP03	8.5	5.6	7.2	15.02	
EQ03	9.5		6.84		
SP04	10.5	5.6	7.2	15.02	
EQ04	9.5		7.86		
SP05	10.5	5.6	7.2	15.02	
EQ05	9.5		8.09		
301	9.5	5.28	8.09	15.02	K=K @ EQ05
302	9.5	5.28	8.37	15.28	K=K @ EQ05
303	9.5	5.28	8.89	15.75	K=K @ EQ05
304	9.5		9.53		
305	9.5		11.17		
306	9.5		14.91		
307	9.5		36.82		
308	30.17		31.1		
TOR	30.17		33.99		
BOR	0.0		50.07		
UG1	0.0		50.29	250.0	
UG2	0.0		52.44		
BFP	0.0		58.06		
TST	-10.0		62.61		
309	9.5	5.74	8.76	17.0	K=K @ EQ03
310	9.5	5.36	8.02	15.18	K=K @ EQ04
311	9.5	5.74	10.32	18.46	K=K @ EQ02
312	9.5	5.74	13.8	21.34	K=K @ EQ02
313	9.5	5.36	14.28	20.25	K=K @ EQ04
314	9.5	5.28	14.56	20.16	K=K @ EQ05
315	9.5	5.59	15.12	21.73	K=K @ EQ01
316	9.5	5.59	16.23	22.52	K=K @ EQ01
317	9.5		18.18		
318	9.5		36.71		
319	9.5	5.74	16.88	23.6	K=K @ EQ02

Final Calculations - Hazen-Williams - 2007

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #3

Page 5
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP02 to EQ02	8.5 9.5	5.60	15.01 15.01	1 1.049	0.0 0.0	1.000 0.0	120 0.0770	7.184 -0.433			
			0.0 15.01					0.077	Vel =	5.57	
EQ02								6.828	K Factor =	5.74	
DP01 to EQ01	8.5 9.5	5.60	15.01 15.01	1 1.049	T 0.0	5.0 5.000	120 0.0765	7.184 -0.433			
			0.0 15.01		0.0	6.000		0.459	Vel =	5.57	
EQ01								7.210	K Factor =	5.59	
DP03 to EQ03	8.5 9.5	5.60	15.02 15.02	1 1.049	0.0 0.0	1.000 0.0	120 0.0770	7.196 -0.433			
			0.0 15.02		0.0	1.000		0.077	Vel =	5.58	
EQ03								6.840	K Factor =	5.74	
SP04 to EQ04	10.5 9.5	5.60	15.02 15.02	1 1.049	E 0.0	2.0 2.000	120 0.0767	7.196 0.433			
			0.0 15.02		0.0	3.000		0.230	Vel =	5.58	
EQ04								7.859	K Factor =	5.36	
SP05 to EQ05	10.5 9.5	5.60	15.02 15.02	1 1.049	T 0.0	5.0 5.000	120 0.0767	7.196 0.433			
			0.0 15.02		0.0	6.000		0.460	Vel =	5.58	
EQ05								8.089	K Factor =	5.28	
301 to 302	9.500 9.5	5.28	30.20 30.2	1.5 1.682	0.0 0.0	10.000 0.0	120 0.0280	8.089 0.0	K = K @ EQ05		
					0.0	10.000		0.280	Vel =	4.36	
302 to 303	9.5 9.5	5.28	15.28 45.48	1.5 1.682	0.0 0.0	8.670 0.0	120 0.0597	8.369 0.0	K = K @ EQ05		
					0.0	8.670		0.518	Vel =	6.57	
303 to 304	9.5 9.5	5.28	15.75 61.23	1.5 1.682	0.0 0.0	6.250 0.0	120 0.1034	8.887 0.0	K = K @ EQ05		
			0.0 17.00		0.0	6.250		0.646	Vel =	8.84	
304 to 305	9.5 9.5		17.00 78.23	1.5 1.682	0.0 0.0	10.080 0.0	120 0.1628	9.533 0.0			
			0.0 18.46		0.0	10.080		1.641	Vel =	11.30	
305 to 306	9.5 9.5		18.46 96.69	1.5 1.682	0.0 0.0	15.500 0.0	120 0.2409	11.174 0.0			
			0.0 21.33		0.0	15.500		3.734	Vel =	13.96	
306 to 307	9.5 9.5		21.33 118.02	1.5 1.682	T 0.0	9.9 9.900	120 0.3483	14.908 0.0			
			0.0 108.26		0.0	62.900		21.910	Vel =	17.04	
307 to 308	9.5 30.17		108.26 226.28	3 3.26	2E T	18.815 20.159	120 0.0463	36.818 -8.952			
			0.0 226.28		0.0	69.974		3.239	Vel =	8.70	
308 to TOR	30.17 30.170		0.0 226.28	3 3.26	E T	9.408 20.159	120 0.0463	31.105 0.0			
					0.0	62.317		2.884	Vel =	8.70	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #3

Page 6
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
TOR to BOR	30.170 0		0.0 226.28	3 3.26	B S 13.44 21.503 0.0	30.170 34.943 65.113	120 0.0463	33.989 13.067 3.013			
BOR to UG1	0 0		0.0 226.28	6 6.16	E T 20.084 43.037 0.0	75.000 63.121 138.121	140 0.0016	50.069 0.0 0.217	Vel =	8.70	
UG1 to UG2	0 0	H250	250.00 476.28	6 6.16	E 2T 20.084 86.075 0.0	240.000 106.159 346.159	140 0.0062	50.286 0.0 2.152	Vel =	5.13	
UG2 to BFP	0 0		0.0 476.28	8 8.27	2E 12.652 55.354 0.0	365.000 56.936 421.936	140 0.0015	52.438 5.000 0.625	* * Fixed Loss = 5 Vel =	2.84	
BFP to TST	0 -10		0.0 476.28	8 8.27	2G T 12.652 55.354 0.0	75.000 68.006 143.006	140 0.0015	58.063 4.331 0.211	Vel =	2.84	
TST			0.0 476.28					62.605	K Factor =	60.19	
309 to 304	9.5 9.5	5.74	17.00 17.0	1 1.049	E T 2.0 5.0 0.0	1.000 7.000 8.000	120 0.0964	8.762 0.0 0.771	K = K @ EQ03 Vel =	6.31	
304			0.0 17.00					9.533	K Factor =	5.51	
310 to 301	9.5 9.500	5.36	15.18 15.18	1.5 1.682	0.0 0.0 0.0	8.500 0.0 8.500	120 0.0078	8.023 0.0 0.066	K = K @ EQ04 Vel =	2.19	
301			0.0 15.18					8.089	K Factor =	5.34	
311 to 305	9.5 9.5	5.74	18.46 18.46	1 1.049	E T 2.0 5.0 0.0	0.580 7.000 7.580	120 0.1121	10.324 0.0 0.850	K = K @ EQ02 Vel =	6.85	
305			0.0 18.46					11.174	K Factor =	5.52	
312 to 306	9.5 9.5	5.74	21.34 21.34	1 1.049	E T 2.0 5.0 0.0	0.580 7.000 7.580	120 0.1467	13.796 0.0 1.112	K = K @ EQ02 Vel =	7.92	
306			0.0 21.34					14.908	K Factor =	5.53	
313 to 314	9.5 9.5	5.36	20.25 20.25	1.5 1.682	2E 9.9 0.0 0.0	11.590 9.900 21.490	120 0.0134	14.277 0.0 0.287	K = K @ EQ04 Vel =	2.92	
314 to 315	9.5 9.5	5.28	20.16 40.41	1.5 1.682	0.0 0.0 0.0	11.500 0.0 11.500	120 0.0480	14.564 0.0 0.552	K = K @ EQ05 Vel =	5.83	
315 to 316	9.5 9.500	5.59	21.73 62.14	1.5 1.682	0.0 0.0 0.0	10.500 0.0 10.500	120 0.1063	15.116 0.0 1.116	K = K @ EQ01 Vel =	8.97	
316 to 317	9.500 9.5	5.59	22.52 84.66	1.5 1.682	0.0 0.0 0.0	10.330 0.0 10.330	120 0.1884	16.232 0.0 1.946	K = K @ EQ01 Vel =	12.22	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
TM Fieldhouse - Area #3

Page 7
Date 08-27-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
317 to 318	9.5 9.5		23.60 108.26	1.5 1.682	T 0.0	9.9 0.0	52.500 9.900	120 0.0	18.178 0.0		
318 to 307	9.5 9.5		0.0 108.26	3 3.26	0.0 0.0	0.0 0.0	9.420 9.420	120 0.0118	36.707 0.0	Vel = 15.63	
307			0.0 108.26						36.818	K Factor = 17.84	
319 to 317	9.5 9.5	5.74	23.60 23.6	1 1.049	E T	2.0 5.0	0.330 7.000	120 0.0	16.882 0.0	K = K @ EQ02	
317			0.0 23.60						1.296	Vel = 8.76	
317									18.178	K Factor = 5.54	