

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241253
Address: 3125 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, September 20, 2024

Corrective Action Required:

2	Misc	-Address pending sidewalk inspection -as graded plot plan required -sod -splash blocks and sump pump discharge to extend 36" from foundation -Address to be properly illuminated -uncover covered water meter
---	------	--

Comments: