

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242186  
Address: 3245 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome:  | Date:                      |
|-------------------------------------------|------------------|-----------|----------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Not Ready | Friday, September 20, 2024 |

Corrective Action Required:

|   |      |                                                                                                                                                                                                   |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -lib bracing not installed to plans (missing in some areas, missing nails, cut, incorrect size)[above stairs]<br>-address broken truss B10<br>-uncover covered rear patio and front porch framing |
|---|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**