

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20242729
Address: 3917 SW FLINTROCK DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed - Stop Work	Friday, September 20, 2024

Corrective Action Required
2 DCM1 ESC REQUIRED NO
FURTHER INSP

EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.

Erosion control measures at the street curb are torn down and no longer serves its intended use and needs to be repaired or replaced.

Erosion control measures protecting the pond is down in the middle and needs to be repaired or replaced

Full lot clean up of liter needs to be done

This is the second letter sent about erosion control .

Please address erosion control before a stop work is placed on this permit

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

(This is a copy of the last inspection completed on 09/12/2024)
KBEARD 09/20/24 time 11:25

Comments: