



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110759, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, October 12, 2011

Partial Correction

1	MISC	OK TO SET UP FOR BUSINESS OPERATION. NO PATIENTS OR PUBLIC PRIOR TO APPROVAL.
Corrective Action Required		
2	MISC	RESOLVE FIRE DEPARTMENT ISSUES
Corrective Action Required		
3	MISC	INSPECTIONS OF ELECTRICAL PANEL TERMINATIONS AND PANEL SCHEDULES IN PROGRESS.
Corrective Action Required		
4	MISC	INTERIOR SIGNAGE SUBJECT TO APPROVAL WHEN COMPLETED
Corrective Action Required		
5	MISC	COMPLETE PLACEMENT OF MISSING ELECTRICAL FACE PLATES BEFORE HOSPITAL PERSONNEL ENTER FACILITY.

Comments: