

Structural Engineering & Design, Inc.

1815 Wright Ave
La Verne, CA 91750
Phone: 909.596.1351 Fax: 909.596.7186

Project Name : JOHNSON STORAGE AND MOVING

Project Number : 24-0917-10

Date : 09/20/24

Street Address: 2225 NE TOWNE CENTRE BLVD
City/State : LEE'S SUMMIT, MO 64064

Scope of Work : STORAGE RACK



9/20/24

Structural
Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S Project: Johnson Storage Project #: 24-0917

TABLE OF CONTENTS 10

Title Page	1
Table of Contents.....	2
Design Data and Definition of Components	3
Critical Configuration	4
Seismic Loads	5 to 6
Column	7
Beam and Connector	8 to 9
Bracing	10
Anchors	11
Base Plate	12
Slab on Grade	13
Other Configurations	14 to 15

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: Johnson Storage

Project #: 24-0917-

Design Data

10

1) The analyses herein conforms to the requirements of the:
2018 IBC Section 2209

ANSI MH 16.1-2012 Specifications for the Design of Industrial Steel Storage Racks "2012 RMI Rack Design Manual"
ASCE 7-16, section 15.5.3

2) Transverse braced frame steel conforms to ASTM A570, Gr.55, with minimum strength, $F_y=55$ ksi
Longitudinal frame beam and connector steel conforms to ASTM A570, Gr.55, with minimum yield, $F_y=55$ ksi
All other steel conforms to ASTM A36, Gr. 36 with minimum yield, $F_y= 36$ ksi


3) Anchor bolts shall be provided by installer per ICC reference on plans and calculations herein.

4) All welds shall conform to AWS procedures, utilizing E70xx electrodes or similar. All such welds shall be performed in shop, with no field welding allowed other than those supervised by a licensed deputy inspector.


5) The existing slab on grade is 6" thick with minimum 4000 psi compressive strength. Allowable Soil bearing capacity is 750 psf. The design of the existing slab is by others.

6) Load combinations for rack components correspond to 2012 RMI Section 2.1 for ASD level load criteria

Definition of Components



Front View: Down Aisle
(Longitudinal) Frame



Section A: Cross Aisle
(Transverse) Frame

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

10

Configuration & Summary: TYPE A SELECTIVE RACK



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 120 lb

AXIAL LL= 12,600 lb

SEISMIC AXIAL Ps= +/- 1,821 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	6	42 in	348.0 in	6	140 in	Single Row

Component		Description							STRESS
Column		Fy=55 ksi	INTLK LU75/3x3x13ga			P=10600 lb, M=15318 in-lb		0.87-OK	
Column & Backer		None	None			None		N/A	
Beam		Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk			Lu=140 in	Capacity: 4309 lb/pr	0.97-OK	
Beam Connector		Fy=55 ksi	Lvl 1: 3 pin OK	Mconn=13125 in-lb		Mcap=15230 in-lb		0.86-OK	
Brace-Horizontal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga					0.05-OK	
Brace-Diagonal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga					0.22-OK	
Base Plate		Fy=36 ksi	7.75x5x0.375				Fixity= 0 in-lb	0.99-OK	
Anchor		2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=872 lb)					0.217-OK	
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure						0.6-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector
1	4,200 lb	12.0 in	52.0 in	6 lb	13 lb	12,720 lb	4,653 "#	9,794 "#	3 pin OK
2	4,200 lb	60.0 in	52.0 in	34 lb	77 lb	10,600 lb	15,318 "#	13,125 "#	3 pin OK
3	4,200 lb	60.0 in	73.0 in	61 lb	140 lb	8,480 lb	14,169 "#	11,985 "#	3 pin OK
4	4,200 lb	60.0 in	73.0 in	89 lb	204 lb	6,360 lb	12,063 "#	10,176 "#	3 pin OK
5	4,200 lb	60.0 in	73.0 in	117 lb	268 lb	4,240 lb	9,000 "#	7,697 "#	3 pin OK
6	4,200 lb	60.0 in	12.0 in	145 lb	332 lb	2,120 lb	4,979 "#	4,547 "#	3 pin OK

** Load defined as product weight per pair of beams Total: 452 lb 1,034 lb

Notes

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

Seismic Forces Configuration: TYPE A SELECTIVE RACK

Lateral analysis is performed with regard to the requirements of the 2012 RMI ANSI MH 16.1-2012 Sec 2.6 & ASCE 7-16 sec 15.5.3

Transverse (Cross Aisle) Seismic Load

$$V = Cs \cdot Ip \cdot Ws = Cs \cdot Ip \cdot (0.67 \cdot P \cdot Prf + D)$$

$$Cs1 = Sds/R$$

$$= 0.0264$$

$$Cs2 = 0.044 \cdot Sds$$

$$= 0.0046$$

$$Cs3 = 0.5 \cdot S1/R$$

$$= 0.0085$$

$$Cs\text{-max} = 0.0264$$

$$\text{Base Shear Coeff} = Cs = \mathbf{0.0264}$$

$$Cs\text{-max} \cdot Ip = 0.0264$$

$$V_{min} = 0.015$$

$$\text{Eff Base Shear} = Cs = 0.0264$$

$$Ws = (0.67 \cdot PL_{RF1} \cdot PL) + DL \text{ (RMI 2.6.2)}$$

$$= 17,124 \text{ lb}$$

$$V_{transv} = Vt = \mathbf{0.0264 \cdot (240 \text{ lb} + 16884 \text{ lb})}$$

$$E_{transverse} = \mathbf{452 \text{ lb}}$$

Limit States Level Transverse seismic shear per upright



Transverse Elevation

$$Ss = 0.099$$

$$S1 = 0.068$$

$$Fa = 1.600$$

$$Fv = 2.400$$

$$Sds = 2/3 \cdot Ss \cdot Fa = 0.106$$

$$Sd1 = 2/3 \cdot S1 \cdot Fv = 0.109$$

$$Ca = 0.4 \cdot 2/3 \cdot Ss \cdot Fa = 0.0422$$

$$\text{(Transverse, Braced Frame Dir.) } R = 4.0$$

$$Ip = 1.0$$

$$P_{RF1} = \mathbf{1.0}$$

$$\text{Pallet Height} = hp = 48.0 \text{ in}$$

$$DL \text{ per Beam Lvl} = 40 \text{ lb}$$

Level	PRODUCT LOAD P	P*0.67*P _{RF1}	DL	hi	wi*hi	Fi	Fi*(hi+hp/2)
1	4,200 lb	2,814 lb	40 lb	12 in	34,248	5.6 lb	202-#
2	4,200 lb	2,814 lb	40 lb	72 in	205,488	33.5 lb	3,216-#
3	4,200 lb	2,814 lb	40 lb	132 in	376,728	61.4 lb	9,578-#
4	4,200 lb	2,814 lb	40 lb	192 in	547,968	89.3 lb	19,289-#
5	4,200 lb	2,814 lb	40 lb	252 in	719,208	117.2 lb	32,347-#
6	4,200 lb	2,814 lb	40 lb	312 in	890,448	145.1 lb	48,754-#

sum: P=25200 lb 16,884 lb 240 lb W=17124 lb 2,774,088 452 lb Σ=113,386

Longitudinal (Downaisle) Seismic Load

Similarly for longitudinal seismic loads, using R=6.0

$$Ws = (0.67 \cdot PL_{RF2} \cdot P) + DL$$

$$= 17,124 \text{ lb}$$

$$P_{RF2} = 1.0$$

$$\text{(Longitudinal, Unbraced Dir.) } R = 6.0$$

$$Cs1 = Sd1/(T \cdot R) = 0.0604$$

$$Cs2 = 0.0046$$

$$Cs = Cs\text{-max} \cdot Ip = 0.0604$$

$$T = 0.30 \text{ sec}$$


$$Cs3 = 0.0057$$

$$Cs\text{-max} = 0.0604$$

$$V_{long} = \mathbf{0.0604 \cdot (240 \text{ lb} + 16884 \text{ lb})}$$

$$E_{longitudinal} = \mathbf{1,034 \text{ lb}}$$

Limit States Level Longit. seismic shear per upright



Front View

Level	PRODUC LOAD P	P*0.67*P _{RF2}	DL	hi	wi*hi	Fi
1	4,200 lb	2,814 lb	40 lb	12 in	34,248	12.8 lb
2	4,200 lb	2,814 lb	40 lb	72 in	205,488	76.6 lb
3	4,200 lb	2,814 lb	40 lb	132 in	376,728	140.4 lb
4	4,200 lb	2,814 lb	40 lb	192 in	547,968	204.2 lb
5	4,200 lb	2,814 lb	40 lb	252 in	719,208	268.1 lb
6	4,200 lb	2,814 lb	40 lb	312 in	890,448	331.9 lb

sum: 16,884 lb 240 lb W=17124 lb 2,774,088 1,034 lb

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

Downaisle Seismic Loads


Configuration: TYPE A SELECTIVE RACK

10

Determine the story moments by applying portal analysis. The base plate is assumed to provide no fixity.

Seismic Story Forces

$$\begin{aligned} V_{long} &= 1,034 \text{ lb} \\ V_{col} &= V_{long}/2 = 517 \text{ lb} \\ F1 &= 13 \text{ lb} \\ F2 &= 77 \text{ lb} \\ F3 &= 140 \text{ lb} \end{aligned}$$




Seismic Story Moments

COL

$$\begin{aligned} M_{base-max} &= 0 \text{ in-lb} <==== \text{Default capacity} \\ M_{base-v} &= (V_{col} * h1_{eff})/2 \\ &= 2,327 \text{ in-lb} <==== \text{Moment going to base} \\ M_{base-eff} &= \text{Minimum of } M_{base-max} \text{ and } M_{base-v} \\ &= 0 \text{ in-lb} \text{ PINNED BASE ASSUMED} \\ M_{1-1} &= [V_{col} * h1_{eff}] - M_{base-eff} \\ &= (517 \text{ lb} * 9 \text{ in}) - 0 \text{ in-lb} \\ &= 4,653 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} h1_{eff} &= h1 - \text{beam clip height}/2 \\ &= 9 \text{ in} \end{aligned}$$

$$\begin{aligned} M_{2-2} &= [V_{col} - (F1)/2] * h2 \\ &= [517 \text{ lb} - 38.3 \text{ lb}] * 60 \text{ in}/2 \\ &= 15,318 \text{ in-lb} \end{aligned}$$



$$M_{seis} = (M_{upper} + M_{lower})/2$$

$$\begin{aligned} M_{seis}(1-1) &= (4653 \text{ in-lb} + 15318 \text{ in-lb})/2 \\ &= 9,986 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} M_{seis}(2-2) &= (15318 \text{ in-lb} + 14169 \text{ in-lb})/2 \\ &= 14,744 \text{ in-lb} \end{aligned}$$

$$\rho = 1.0000$$

Summary of Forces

LEVEL	hi	Axial Load	Column Moment**	Mseismic**	Mend-fixity	Mconn**	Beam Connector
1	12 in	12,720 lb	4,653 in-lb	9,986 in-lb	4,006 in-lb	9,794 in-lb	3 pin OK
2	60 in	10,600 lb	15,318 in-lb	14,744 in-lb	4,006 in-lb	13,125 in-lb	3 pin OK
3	60 in	8,480 lb	14,169 in-lb	13,116 in-lb	4,006 in-lb	11,985 in-lb	3 pin OK
4	60 in	6,360 lb	12,063 in-lb	10,532 in-lb	4,006 in-lb	10,176 in-lb	3 pin OK
5	60 in	4,240 lb	9,000 in-lb	6,989 in-lb	4,006 in-lb	7,697 in-lb	3 pin OK
6	60 in	2,120 lb	4,979 in-lb	2,489 in-lb	4,006 in-lb	4,547 in-lb	3 pin OK

$$\begin{aligned} M_{conn} &= (M_{seismic} + M_{end-fixity}) * 0.70 * \rho \\ M_{conn-allow}(3 \text{ Pin}) &= 15,230 \text{ in-lb} \end{aligned}$$

**all moments based on limit states level loading

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: Johnson Storage

Project #: 24-0917

Column (Longitudinal Loads)

Configuration: TYPE A SELECTIVE RACK

10

Section Properties

Section: INTLK LU75/3x3x13ga

$A_{eff} = 0.757 \text{ in}^2$

$I_x = 1.320 \text{ in}^4$

$S_x = 0.879 \text{ in}^3$

$r_x = 1.320 \text{ in}$

$\Omega_f = 1.67$

$E = 29,500 \text{ ksi}$

$I_y = 0.871 \text{ in}^4$

$S_y = 0.574 \text{ in}^3$

$r_y = 1.080 \text{ in}$

$F_y = 55 \text{ ksi}$

$C_{mx} = 0.85$


$K_x = 1.7$

$L_x = 57.5 \text{ in}$

$K_y = 1.0$

$L_y = 52.0 \text{ in}$

$C_b = 1.0$



Loads

Considers loads at level 2

COLUMN DL= 100 lb

COLUMN PL= 10,500 lb

Mcol= 15,318 in-lb

Sds= 0.1056

$1+0.105S_{ds} = 1.0111$

$1.4+0.14S_{ds} = 1.4148$

$1+0.14S_{ds} = 1.0148$

$0.85+0.14S_{ds} = 0.8648$

B= 0.7000

$\rho = 1.0000$

Critical load cases are: RMI Sec 2.1

Load Case 5: $(1+0.105S_{ds})D + 0.75(1.4+0.14S_{ds})B^*P + 0.75(0.7\rho E) \leq 1.0$, ASD Method

axial load coeff: $0.7427616 * P$ seismic moment coeff: $0.5625 * M_{col}$

Load Case 6: $(1+0.14S_{ds})D + (0.85+0.14S_{ds})B^*P + (0.7\rho E) \leq 1.0$, ASD Method

axial load coeff: 0.60535 seismic moment coeff: $0.7 * M_{col}$

By analysis, Load case 5 governs utilizing loads as such

Axial Load= $P_{ax} = 1.011088 * 100 \text{ lb} + 0.75 * 1.414784 * 0.7 * 10500 \text{ lb}$
= **7,900 lb**

Moment= $M_x = 0.75 * 0.7\rho E * M_{col}$
= **0.525 * 15318 in-lb**
= **8,042 in-lb**

Axial Analysis

$K_x L_x / r_x = 1.7 * 57.5 / 1.3196$
= 74.1

$K_y L_y / r_y = 1 * 52 / 1.08$
= 48.1

$F_e > F_y / 2$

$F_n = F_y (1 - F_y / 4 F_e)$
= $55 \text{ ksi} * [1 - 55 \text{ ksi} / (4 * 53.1 \text{ ksi})]$
= 40.7 ksi

$P_a = P_n / \Omega_c$
= $30846 \text{ lb} / 1.92$
= 16,066 lb

$F_e = \pi^2 E / (K L / r)^2$
= 53.1 ksi

$F_y / 2 = 27.5 \text{ ksi}$

$P_n = A_{eff} * F_n$
= 30,846 lb

$\Omega_c = 1.92$

$P / P_a = 0.49 > 0.15$

Bending Analysis

Check: $P_{ax} / P_a + (C_{mx} * M_x) / (M_{ax} * \mu_x) \leq 1.0$

$P / P_{ao} + M_x / M_{ax} \leq 1.0$

$P_{no} = A_e * F_y$
= $0.757 \text{ in}^2 * 55000 \text{ psi}$
= 41,635 lb

$P_{ao} = P_{no} / \Omega_c$
= $41635 \text{ lb} / 1.92$
= 21,685 lb

$M_{yield} = M_y = S_x * F_y$
= $0.879 \text{ in}^3 * 55000 \text{ psi}$
= 48,345 in-lb

$M_{ax} = M_y / \Omega_f$
= $48345 \text{ in-lb} / 1.67$
= 28,949 in-lb

$P_{cr} = \pi^2 EI / (K L)^2$
= $\pi^2 * 29500 \text{ ksi} / (1.7 * 57.5 \text{ in})^2$
= 40,222 lb

$\mu_x = \{1 / [1 - (\Omega_c * P / P_{cr})]\}^{-1}$
= $\{1 / [1 - (1.92 * 7900 \text{ lb} / 40222 \text{ lb})]\}^{-1}$
= 0.62

Combined Stresses

$(7900 \text{ lb} / 16066 \text{ lb}) + (0.85 * 8042 \text{ in-lb}) / (28949 \text{ in-lb} * 0.62) = 0.87 < 1.0$, OK (EQ C5-1)

$(7900 \text{ lb} / 21685 \text{ lb}) + (8042 \text{ in-lb} / 28949 \text{ in-lb}) = 0.64 < 1.0$, OK (EQ C5-2)

** For comparison, total column stress computed for load case 6 is: 70.0%

zing loads 6457.6408 lb Axial and $M = 10722 \text{ in-lb}$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: Johnson Storage

Project #: 24-0917

BEAM

Configuration: TYPE A SELECTIVE RACK

10


DETERMINE ALLOWABLE MOMENT CAPACITY

A) Check compression flange for local buckling (B2.1)

$$\begin{aligned} w &= c - 2*t - 2*r \\ &= 1.75 \text{ in} - 2*0.059 \text{ in} - 2*0.059 \text{ in} \\ &= 1.514 \text{ in} \\ w/t &= 25.66 \\ l=\lambda &= [1.052/(k)^{0.5}] * (w/t) * (F_y/E)^{0.5} \\ &= [1.052/(4)^{0.5}] * 25.66 * (55/29500)^{0.5} \\ &= 0.583 < 0.673, \text{ Flange is fully effective} \end{aligned}$$

Eq. B2.1-4

Eq. B2.1-1



B) check web for local buckling per section b2.3

$$\begin{aligned} f_1(\text{comp}) &= F_y * (y_3/y_2) = 51.18 \text{ ksi} \\ f_2(\text{tension}) &= F_y * (y_1/y_2) = 102.95 \text{ ksi} \\ Y &= f_2/f_1 \\ &= -2.012 \\ k &= 4 + 2*(1-Y)^3 + 2*(1-Y) \\ &= 64.67 \\ \text{flat depth} &= w = y_1 + y_3 \\ &= 4.764 \text{ in} \\ l=\lambda &= [1.052/(k)^{0.5}] * (w/t) * (f_1/E)^{0.5} \\ &= [1.052/(64.67)^{0.5}] * 4.764 * (51.18/29500)^{0.5} \\ &= 0.44 < 0.673 \\ b_e &= w = 4.764 \text{ in} \\ b_1 &= b_e(3-Y) = 0.951 \\ b_2 &= b_e/2 = 2.38 \text{ in} \\ b_1 + b_2 &= 3.331 \text{ in} > 1.582 \text{ in, Web is fully effective} \end{aligned}$$

Eq. B2.3-5

Eq. B2.3-4

OK

Eq B2.3-2

Beam= Intlk 50E 5Hx2.75Wx0.059"Thk

I_x	2.916 in^4
S_x	1.114 in^3
Y_{cg}	3.300 in
t	0.059 in
Bend Radius= r	0.059 in
$F_y = F_{yv}$	55.00 ksi
$F_u = F_{uv}$	65.00 ksi
E	29500 ksi
top flange= b	1.750 in
bottom flange= b	2.750 in
Web depth= d	5.000 in

Determine effect of cold working on steel yield point (F_{ya}) per section A7.2


$$\begin{aligned} F_{ya} &= C * F_{yc} + (1-C) * F_y \quad (\text{EQ A7.2-1}) \\ L_{\text{corner}} &= L_c = (p/2) * (r + t/2) \\ &= 0.139 \text{ in} \\ C &= 2 * L_c / (L_f + 2 * L_c) \\ L_{\text{flange-top}} &= L_f = 1.514 \text{ in} \\ m &= 0.192 * (F_u/F_y) - 0.068 \quad (\text{EQ A7.2-4}) \\ &= 0.1590 \\ B_c &= 3.69 * (F_u/F_y) - 0.819 * (F_u/F_y)^2 - 1.79 \\ &= 1.427 \\ \text{since } f_u/F_v &= 1.18 < 1.2 \\ \text{and } r/t &= 1 < 7 \text{ OK} \\ \text{then } F_{yc} &= B_c * F_y / (R/t)^m \quad (\text{EQ A7.2-2}) \\ &= 78.485 \text{ ksi} \end{aligned}$$

$$\begin{aligned} \text{Thus, } F_{ya-\text{top}} &= 58.64 \text{ ksi} \quad (\text{tension stress at top}) \\ F_{ya-\text{bottom}} &= F_{ya} * Y_{cg} / (\text{depth} - Y_{cg}) \\ &= 113.84 \text{ ksi} \quad (\text{tension stress at bottom}) \end{aligned}$$

Check allowable tension stress for bottom flange

$$\begin{aligned} L_{\text{flange-bot}} &= L_{fb} = L_{\text{bottom}} - 2 * r - 2 * t \\ &= 2.514 \text{ in} \\ C_{\text{bottom}} &= C_b = 2 * L_c / (L_{fb} + 2 * L_c) \\ &= 0.100 \\ F_{y-\text{bottom}} &= F_{yb} = C_b * F_{yc} + (1 - C_b) * F_y \\ &= 57.34 \text{ ksi} \\ F_{ya} &= (F_{ya-\text{top}}) * (F_{yb} / F_{ya-\text{bottom}}) \\ &= 29.54 \text{ ksi} \\ \text{if } F &= 0.95 \end{aligned}$$

$$\text{Then } F * M_n = F * F_{ya} * S_x = 31.26 \text{ in-k}$$



$$\begin{aligned} y_1 &= Y_{cg} - t - r = 3.182 \text{ in} \\ y_2 &= \text{depth} - Y_{cg} = 1.700 \text{ in} \\ y_3 &= y_2 - t - r = 1.582 \text{ in} \end{aligned}$$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

BEAM

Configuration: TYPE A SELECTIVE RACK

10

RMI Section 5.2, PT II

Section

Beam= Intlk 50E 5Hx2.75Wx0.059"Thk

$I_x = I_y = 2.916 \text{ in}^4$

$S_x = 1.114 \text{ in}^3$

$t = 0.059 \text{ in}$

$E = 29500 \text{ ksi}$

$F_y = F_{yv} = 55 \text{ ksi}$

$F = 240.0$

$F_u = F_{uv} = 65 \text{ ksi}$


$L = 140 \text{ in}$

$F_{ya} = 58.6 \text{ ksi}$

Beam Level= 1

$P = \text{Product Load} = 4,200 \text{ lb/pair}$

$D = \text{Dead Load} = 40 \text{ lb/pair}$



1. Check Bending Stress Allowable Loads

$$M_{center} = F \cdot M_n = W \cdot L \cdot W \cdot R_m / 8$$

W=LRFD Load Factor= $1.2 \cdot D + 1.4 \cdot P + 1.4 \cdot (0.125) \cdot P$
FOR DL=2% of PL,

RMI 2.2, item 8

$$W = 1.599$$

$$R_m = 1 - [(2 \cdot F \cdot L) / (6 \cdot E \cdot I_b + 3 \cdot F \cdot L)]$$

$$= 1 - (2 \cdot 240 \cdot 140 \text{ in}) / [(6 \cdot 29500 \text{ ksi} \cdot 2.9155 \text{ in}^4) + (3 \cdot 240 \cdot 140 \text{ in})]$$

$$= 0.891$$

$$\text{if } F = 0.95$$

$$\text{Then } F \cdot M_n = F \cdot F_{ya} \cdot S_x = 62.06 \text{ in-k}$$

Thus, allowable load

$$\text{per beam pair} = W = F \cdot M_n \cdot 8 \cdot (\# \text{ of beams}) / (L \cdot R_m \cdot W)$$

$$= 62.06 \text{ in-k} \cdot 8 \cdot 2 / (140 \text{ in} \cdot 0.891 \cdot 1.599)$$


$$= \mathbf{4,979 \text{ lb/pair}} \quad \text{allowable load based on bending stress}$$

$$M_{end} = W \cdot L \cdot (1 - R_m) / 8$$

$$= (4979 \text{ lb/2}) \cdot 140 \text{ in} \cdot (1 - 0.891) / 8$$

$$= 4,749 \text{ in-lb} \quad @ \text{ 4979 lb max allowable load}$$

$$= 4,006 \text{ in-lb} \quad @ \mathbf{4200 \text{ lb imposed product load}}$$



2. Check Deflection Stress Allowable Loads

$$D_{max} = D_{ss} \cdot R_d$$

$$R_d = 1 - (4 \cdot F \cdot L) / (5 \cdot F \cdot L + 10 \cdot E \cdot I_b)$$

$$= 1 - (4 \cdot 240 \cdot 140 \text{ in}) / (5 \cdot 240 \cdot 140 \text{ in} + (10 \cdot 29500 \text{ ksi} \cdot 2.9155 \text{ in}^4))$$

$$= 0.869 \text{ in}$$

$$\text{if } D_{max} = L / 180 \quad \text{Based on } L / 180 \text{ Deflection Criteria}$$

$$\text{and } D_{ss} = 5 \cdot W \cdot L^3 / (384 \cdot E \cdot I_b)$$

$$\text{Allowable Deflection} = L / 180$$

$$= 0.778 \text{ in}$$

$$\text{Deflection at imposed Load} = 0.758 \text{ in}$$

$$L / 180 = 5 \cdot W \cdot L^3 \cdot R_d / (384 \cdot E \cdot I_b \cdot \# \text{ of beams})$$

solving for W yields,

$$W = 384 \cdot E \cdot I_b \cdot 2 / (180 \cdot 5 \cdot L^2 \cdot R_d)$$

$$= 384 \cdot 2.9155 \text{ in}^4 \cdot 2 / [180 \cdot 5 \cdot (140 \text{ in})^2 \cdot 0.869]$$

$$= \mathbf{4,309 \text{ lb/pair}} \quad \text{allowable load based on deflection limits}$$

Thus, based on the least capacity of item 1 and 2 above:

Allowable load= 4,309 lb/pair
Imposed Product Load= 4,200 lb/pair

Beam Stress= 0.97

Beam at Level 1

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

3 Pin Beam to Column Connection


TYPE A SELECTIVE RACK

10

The beam end moments shown herein show the result of the maximum induced fixed end moments from seismic + static loads and the code mandated minimum value of 1.5%(DL+PL)

$$\begin{aligned} M_{conn \max} &= (M_{seismic} + M_{end-fixity}) * 0.70 * \rho \\ &= 13,125 \text{ in-lb} \quad \text{Load at level 2} \end{aligned}$$

$$\rho = 1.0000$$



Connector Type= 3 Pin

Shear Capacity of Pin

$$\text{Pin Diam} = 0.44 \text{ in}$$

$$F_y = 55,000 \text{ psi}$$

$$\begin{aligned} A_{shear} &= (0.438 \text{ in})^2 * \pi / 4 \\ &= 0.1507 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} P_{shear} &= 0.4 * F_y * A_{shear} \\ &= 0.4 * 55,000 \text{ psi} * 0.1507 \text{ in}^2 \\ &= 3,315 \text{ lb} \end{aligned}$$

Bearing Capacity of Pin

$$t_{col} = 0.090 \text{ in}$$

$$F_u = 65,000 \text{ psi}$$

$$\Omega = 2.22$$

$$a = 2.22$$

$$\begin{aligned} P_{bearing} &= \alpha * F_u * \text{diam} * t_{col} / \Omega \\ &= 2.22 * 65,000 \text{ psi} * 0.438 \text{ in} * 0.09 \text{ in} / 2.22 \\ &= 2,562 \text{ lb} < 3,315 \text{ lb} \end{aligned}$$

Moment Capacity of Bracket

$$\text{Edge Distance} = E = 1.00 \text{ in}$$

$$\text{Pin Spacing} = 2.0 \text{ in}$$

$$F_y = 55,000 \text{ psi}$$

$$\begin{aligned} C &= P_1 + P_2 + P_3 \\ &= P_1 + P_1 * (2.5" / 4.5") + P_1 * (0.5" / 4.5") \\ &= 1.667 * P_1 \end{aligned}$$

$$t_{clip} = 0.18 \text{ in}$$

$$S_{clip} = 0.127 \text{ in}^3$$

$$\begin{aligned} M_{cap} &= S_{clip} * F_{bending} \\ &= 0.127 \text{ in}^3 * 0.66 * F_y \\ &= 4,610 \text{ in-lb} \end{aligned}$$

$$C * d = M_{cap} = 1.667$$

$$\begin{aligned} d &= E / 2 \\ &= 0.50 \text{ in} \end{aligned}$$

$$\begin{aligned} P_{clip} &= M_{cap} / (1.667 * d) \\ &= 4,610.1 \text{ in-lb} / (1.667 * 0.5 \text{ in}) \\ &= 5,531 \text{ lb} \end{aligned}$$

$$\text{Thus, } P_1 = 2,562 \text{ lb}$$

$$\begin{aligned} M_{conn-allow} &= [P_1 * 4.5" + P_1 * (2.5" / 4.5") * 2.5" + P_1 * (0.5" / 4.5") * 0.5"] \\ &= 2,562 \text{ LB} * [4.5" + (2.5" / 4.5") * 2.5" + (0.5" / 4.5") * 0.5"] \\ &= 15,230 \text{ in-lb} > M_{conn \max}, \text{ OK} \end{aligned}$$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

Transverse Brace

Configuration: TYPE A SELECTIVE RACK

10

Section Properties

Diagonal Member= Intlk 1-1/2x1-1/2x14ga


Area= 0.315 in²

r min= 0.488 in

Fy= 55,000 psi

K= 1.0

Ωc= 1.92




Horizontal Member= Intlk 1-1/2x1-1/2x14ga

Area= 0.315 in²

r min= 0.488 in

Fy= 55,000 psi

K= 1.0



Frame Dimensions

Bottom Panel Height=H= 73.0 in

Frame Depth=D= 42.0 in

Column Width=B= 3.0 in

Clear Depth=D-B*2= 36.0 in

X Brace= NO

rho= 1.00

Diagonal Member

Load Case 6: : $(1+0.104*Sds)D + [(0.85+0.14Sds)*B*P + [0.7*\rho*E]] \leq 1.0$, ASD Method

Vtransverse= 452 lb

Vb=Vtransv*0.7*rho= 452 lb * 0.7 * 1

= 316 lb

Ldiag= $[(D-B*2)^2 + (H-6'')^2]^{1/2}$

= 76.1 in

Pmax= V*(Ldiag/D) * 0.75

= 430 lb

axial load on diagonal brace member

Pn= AREA*Fn

= 0.315 in² * 11979 psi

= 3,773 lb

$(kl/r) = (k * Ldiag)/r \text{ min}$
= (1 x 76.1 in / 0.488 in)

= 155.9 in


Fe= $\pi^2 * E / (kl/r)^2$

= 11,979 psi

Since Fe < Fy/2,

Fn= Fe

= 11,979 psi



Pallow= Pn/Ω

= 3773 lb / 1.92

= 1,965 lb

Pn/Pallow= 0.22 <= 1.0 OK

Check End Weld

Lweld= 3.0 in

Fu= 65 ksi

tmin= 0.075 in

Weld Capacity= 0.75 * tmin * L * Fu/2.5

= 4,388 lb OK

Horizontal brace

Vb=Vtransv*0.7*rho= 316 lb

$(kl/r) = (k * Lhoriz)/r \text{ min}$

= (1 x 42 in) / 0.488 in

= 86.1 in

Since Fe > Fy/2, Fn= Fy*(1-fy/4fe)

= 35,745 psi

Fe= $\pi^2 * E / (kl/r)^2$

= 39,275 psi

Fy/2= 27,500 psi

Pn= AREA*Fn

= 0.315 in² * 35745 psi

= 11,260 lb

Pallow= Pn/Ωc

= 11260 lb / 1.92

= 5,864 lb

Pn/Pallow= 0.05 <= 1.0 OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S Project: ~~Johnson Storage~~ Project #: ~~24-0917~~
Single Row Frame Overturning Configuration: TYPE A SELECTIVE RACK **10**

Loads

Critical Load case(s):


1) RMI Sec 2.2, item 7: $(0.9-0.2Sds)D + (0.9-0.20Sds)*B*Papp - E*\rho$

$V_{trans}=V=E=Q_e= 452 \text{ lb}$
DEAD LOAD PER UPRIGHT= $D= 240 \text{ lb}$
PRODUCT LOAD PER UPRIGHT= $P= 25,200 \text{ lb}$
 $Papp=P*0.67= 16,884 \text{ lb}$
 $Wst \text{ LC1}=Wst1=(0.87888*D + 0.87888*Papp*1)= 15,049 \text{ lb}$

$Sds= 0.1056$
 $(0.9-0.2Sds)= 0.8789$
 $(0.9-0.2Sds)= 0.8789$
 $B= 1.0000$
 $\rho= 1.0000$

Product Load Top Level, $P_{top}= 4,200 \text{ lb}$
 $DL/Lvl= 40 \text{ lb}$
Seismic Ovt based on E, $\Sigma(F_i*hi)= 76,494 \text{ in-lb}$
height/depth ratio= 7.4 in

Frame Depth= $D_f= 42.0 \text{ in}$
 $H_{top-lvl}=H= 312.0 \text{ in}$
Levels= 6
Anchors/Base= 2
 $hp= 48.0 \text{ in}$



SIDE ELEVATION

$h=H+hp/2= 336.0 \text{ in}$

A) Fully Loaded Rack

Load case 1:

$Movt= \Sigma(F_i*hi)*E*\rho$
 $= 76,494 \text{ in-lb}$

$Mst= Wst1 * D_f/2$
 $= 15049 \text{ lb} * 42 \text{ in}/2$
 $= 316,029 \text{ in-lb}$

$T= (Movt-Mst)/D_f$
 $= (76494 \text{ in-lb} - 316029 \text{ in-lb})/42 \text{ in}$
 $= -5,703 \text{ lb}$ **No Uplift**

Net Seismic Uplift= -5,703 lb

B) Top Level Loaded Only

Load case 1:

$\square V1=V_{top}= Cs * I_p * P_{top} \geq 350 \text{ lb}$ for $H/D > 6.0$
 $= 0.0264 * 4200 \text{ lb}$
 $= 111 \text{ lb}$

$V1_{eff}= 350 \text{ lb}$

$V2=V_{DL}= Cs*I_p*D$
 $= 6 \text{ lb}$

$Mst= (0.87888*D + 0.87888*P_{top}*1) * 42 \text{ in}/2$
 $= 81,947 \text{ in-lb}$

Critical Level= 6
 $Cs*I_p= 0.0264$

$Movt= [V1*h + V2 * H/2]*\rho$
 $= 118,588 \text{ in-lb}$

$T= (Movt-Mst)/D_f$
 $= (118588 \text{ in-lb} - 81947 \text{ in-lb})/42 \text{ in}$
 $= 872 \text{ lb}$ **Net Uplift per Column**

Net Seismic Uplift= 872 lb

Anchor

Check (2) 0.5" x 3.25" Embed POWERS SD1 anchor(s) per base plate.

Special inspection is not required per ESR 2818.

Pullout Capacity= $T_{cap}= 1,961 \text{ lb}$
Shear Capacity= $V_{cap}= 2,517 \text{ lb}$

L.A. City Jurisdiction? NO
 $\Phi= 1$

$T_{cap}*\Phi= 1,961 \text{ lb}$
 $V_{cap}*\Phi= 2,517 \text{ lb}$

Fully Loaded: $(113 \text{ lb}/2517 \text{ lb})^{\wedge}1 = 0.04 \leq 1.2 \text{ OK}$

Top Level Loaded: $(436 \text{ lb}/1961 \text{ lb})^{\wedge}1 + (87 \text{ lb}/2517 \text{ lb})^{\wedge}1 = 0.26 \leq 1.2 \text{ OK}$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

Base Plate

Configuration: TYPE A SELECTIVE RACK

10

Section

Baseplate= 7.75x5x0.375

Eff Width=W = 7.15 in

Eff Depth=D = 5.00 in

Column Width=b = 3.00 in

Column Depth=dc = 3.00 in

L = 2.08 in


Plate Thickness=t = 0.375 in

a = 2.58 in

Anchor c.c. = 2*a=d = 5.15 in

N=# Anchor/Base= 2

Fy = 36,000 psi



Downaisle Elevation

Down Aisle Loads Load Case 5: $(1+0.105*Sds)D + 0.75*[(1.4+0.14Sds)*B*P + 0.75*[0.7*\rho*E]] \leq 1.0$, ASD Method

COLUMN DL= 120 lb

COLUMN PL= 12,600 lb

Base Moment= 0 in-lb

$1+0.105*Sds = 1.0111$

$1.4+0.14Sds = 1.4148$

B= 0.7000

Axial=P= 1.011088 * 120 lb + 0.75 * (1.414784 * 0.7 * 12600 lb)

= 9,480 lb

Mb= Base Moment*0.75*0.7*rho

= 0 in-lb * 0.75*0.7*rho

= 0 in-lb

Axial Load P = 9,480 lb

Mbase=Mb = 0 in-lb

Axial stress=fa = P/A = P/(D*W)

= 265 psi

Moment Stress=fb = M/S = 6*Mb/[(D*B^2)]

= 0.0 psi

Moment Stress=fb1 = fb-fb2

= 0.0 psi

M3 = $(1/2)*fb2*L*(2/3)*L = (1/3)*fb2*L^2$

= 0 in-lb

S-plate = $(1)(t^2)/6$

= 0.023 in^3/in

fb/Fb = Mtotal/[(S-plate)(Fb)]

= **0.90 OK**

Tanchor = $(Mb-(PLapp*0.75*0.46)(a))/[(d)*N/2]$

= -7,525 lb

No Tension

M1= $wL^2/2 = fa*L^2/2$

= 571 in-lb

Moment Stress=fb2 = $2 * fb * L/W$

= 0.0 psi

M2= $fb1*L^2/2$

= 0 in-lb

Mtotal = M1+M2+M3

= 571 in-lb/in

Fb = 0.75*Fy

= 27,000 psi

F'p = 0.7*F'c

= 2,800 psi

OK

Tallow = 1,961 lb

OK

Cross Aisle Loads Critical load case RMI Sec 2.1, Item 4: $(1+0.11Sds)DL + (1+0.14Sds)PL*0.75+EL*0.75 \leq 1.0$, ASD Method

Pstatic= 9,480 lb

Movt*0.75*0.7*rho= 40,159 in-lb

Frame Depth= 42.0 in

P=Pstatic+Pseismic= 10,436 lb

b =Column Depth= 3.00 in

L =Base Plate Depth-Col Depth= 2.08 in

fa = P/A = P/(D*W)

= 292 psi

Sbase/in = $(1)(t^2)/6$

= 0.023 in^3/in

fb/Fb = M/[(S-plate)(Fb)]

= **0.99 OK**

Pseismic= Movt/Frame Depth

= 956 lb

M= $wL^2/2 = fa*L^2/2$

= 628 in-lb/in


Fbase = 0.75*Fy

= 27,000 psi

Check uplift load on Baseplate

Check uplift forces on baseplate with 2 or more anchors per RMI 7.2.2.

"When the base plate configuration consists of two anchor bolts located on either side of the column and a net uplift force exists, the minimum base plate thickness shall be determined based on a design bending moment in the plate equal to the uplift force on one anchor times 1/2 the distance from the centerline of the anchor to the nearest edge of the rack column"



Uplift per Column= 872 lb

Qty Anchor per BP= 2

Net Tension per anchor=Ta= 436 lb

c= 2.08 in

Mu=Moment on Baseplate due to uplift= Ta*c/2

= 452 in-lb

Splate= 0.117 in^3

$[fb/Fb]*0.75 = 0.107$

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By:

Project:


Project #:

Slab on Grade

Configuration: TYPE 1 SELECTIVE RACK



SLAB ELEVATION



Baseplate Plan View

Concrete

$f'_c = 4,000$ psi

$t_{slab} = t = 6.0$ in

$t_{eff} = 6.0$ in

$\phi = 0.6$

Soil

$f_{soil} = 750$ psf

$Movt = 76,494$ in-lb

Frame depth = 42.0 in

$Sds = 0.106$

$0.2 * Sds = 0.021$

$\lambda = 0.600$

$\beta = B/\Delta = 1.430$

$F'_c^{0.5} = 63.20$ psi

$ks = 50.00$ psi

$R1 = 5.0$ in

$E_c = 3,443,668$ psi

$u = 0.15$

Base Plate

Effec. Baseplate width= $B = 7.15$ in

Effec. Baseplate Depth= $D = 5.00$ in

width= $a = 3.00$ in

depth= $b = 3.00$ in

midway dist face of column to edge of plate= $c = 5.08$ in

midway dist face of column to edge of plate= $e = 4.00$ in

Column Loads

DEAD LOAD= $D = 120$ lb per column

unfactored ASD load

PRODUCT LOAD= $P = 12,600$ lb per column

unfactored ASD load

$P_{app} = 8,442$ lb per column

P-seismic= $E = (Movt/Frame\ depth)$

$= 1,821$ lb per column

unfactored Limit State load

$B = 0.7000$

$\rho = 1.0000$

$Sds = 0.1056$

$1.2 + 0.2 * Sds = 1.2211$

$0.9 - 0.20Sds = 0.8789$

Load Case 1) $(1.2 + 0.2Sds)D + (1.2 + 0.2Sds) * B * P + \rho * E$ RMI SEC 2.2 EQTN 5

$= 1.22112 * 120 \text{ lb} + 1.22112 * 0.7 * 12600 \text{ lb} + 1 * 1821 \text{ lb}$

$= 12,738 \text{ lb}$

Load Case 2) $(0.9 - 0.2Sds)D + (0.9 - 0.2Sds) * B * P_{app} + \rho * E$ RMI SEC 2.2 EQTN 7

$= 0.87888 * 120 \text{ lb} + 0.87888 * 0.7 * 8442 \text{ lb} + 1 * 1821 \text{ lb}$

$= 7,120 \text{ lb}$

Load Case 3) $1.2 * D + 1.4 * P$ RMI SEC 2.2 EQTN 1,2

$= 1.2 * 120 \text{ lb} + 1.4 * 12600 \text{ lb}$

$= 17,784 \text{ lb}$

Load Case 4) $1.2 * D + 1.0 * P + 1.0E$ ACI 318-11 Sec 9.2.1, Eqtn 9-5

$= 14,565 \text{ lb}$

Effective Column Load= $P_u = 17,784$ lb per column

$f'_t = 7.5(f'_c)^{0.5} = 474.341649$

$d_{req} = \{P_u * FS / [1.72 * ((ks * R1 / E_c) * 10^4 + 3.6) * f'_t * \beta]\}^{0.5}$ Factor of Safety = 3

$= 3.887977496$

$\beta = 1$ for $d < 7.0$ in

$b = (E_c * d_{req}^3 / (12 * (1 - u^2) * ks))^{0.25}$

$\beta = 0.85$ for $d > 7.0$ in

$= 24.23712605$

$b_{req} = 1.5 * b = 36.35568908$

If depth of frame $< 2 * b_{req}$,

$P_{u_new} = 2 * P_{u_old} = 35568$

If depth of frame $> \text{or} = 2 * b_{req}$

P_u remains as of before

$P_n = 1.72 * [(ks * R1 / E_c) * 10^4 + 3.6] * f'_t * t^2$

$= 1.72 * [(50 * 5 / 3443668) * 10^4 + 3.6] * 474.341649025257 * 6^2$

$= 127059.084$

$P_a = P_n / FS = 42353.028$

$P_u / P_a = 0.60$

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

Configuration & Summary: TYPE A1 SELECTIVE RACK

10



****RACK COLUMN REACTIONS**

ASD LOADS

AXIAL DL= 120 lb

AXIAL LL= 12,000 lb

SEISMIC AXIAL Ps= +/- 1,737 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	6	42 in	348.0 in	6	144 in	Single Row

Component		Description							STRESS
Column	Fy=55 ksi	INTLK LU75/3x3x13ga				P=10100 lb, M=14607 in-lb		0.82-OK	
Column & Backer	None	None				None		N/A	
Beam	Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk				Lu=144 in	Capacity: 4097 lb/pr	0.98-OK	
Beam Connector	Fy=55 ksi	Lvl 1: 3 pin OK	Mconn=12689 in-lb			Mcap=15230 in-lb		0.83-OK	
Brace-Horizontal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.05-OK
Brace-Diagonal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.21-OK
Base Plate	Fy=36 ksi	7.75x5x0.375					Fixity= 0 in-lb		0.95-OK
Anchor	2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=960 lb)							0.233-OK
Slab & Soil	6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.56-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector
1	4,000 lb	12.0 in	52.0 in	5 lb	12 lb	12,120 lb	4,437 "#	9,513 "#	3 pin OK
2	4,000 lb	60.0 in	52.0 in	32 lb	73 lb	10,100 lb	14,607 "#	12,689 "#	3 pin OK
3	4,000 lb	60.0 in	73.0 in	59 lb	134 lb	8,080 lb	13,512 "#	11,603 "#	3 pin OK
4	4,000 lb	60.0 in	73.0 in	85 lb	195 lb	6,060 lb	11,504 "#	9,877 "#	3 pin OK
5	4,000 lb	60.0 in	73.0 in	112 lb	256 lb	4,040 lb	8,582 "#	7,513 "#	3 pin OK
6	4,000 lb	60.0 in	12.0 in	138 lb	317 lb	2,020 lb	4,748 "#	4,509 "#	3 pin OK

** Load defined as product weight per pair of beams

Total: 431 lb 986 lb

Notes

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: **Johnson Storage**

Project #: **24-0917**

Configuration & Summary: TYPE T INTERIOR TUNNEL SELECTIVE RACK

10



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 120 lb

AXIAL LL= 9,150 lb

SEISMIC AXIAL Ps= +/- 1,405 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	3	42 in	348.0 in	6	144 in	Single Row

Component		Description							STRESS	
Column		Fy=55 ksi	INTLK LU75/3x3x13ga				P=8200 lb, M=11243 in-lb		0.63-OK	
Column & Backer		None	None				None		N/A	
Beam		Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk				Lu=144 in	Capacity: 4097 lb/pr	0.98-OK	
Beam Connector		Fy=55 ksi	Lvl 4: 3 pin OK		Mconn=8856 in-lb		Mcap=15230 in-lb		0.58-OK	
Brace-Horizontal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.04-OK
Brace-Diagonal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.16-OK
Base Plate		Fy=36 ksi	7.75x5x0.375					Fixity= 0 in-lb		0.73-OK
Anchor		2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=960 lb)							0.233-OK
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.41-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector	

4	4,000 lb	60.0 in	73.0 in	73 lb	166 lb	6,060 lb	9,831 "#	8,856 "#	3 pin OK
5	4,000 lb	60.0 in	73.0 in	96 lb	219 lb	4,040 lb	7,335 "#	6,835 "#	3 pin OK
6	4,000 lb	60.0 in	12.0 in	118 lb	271 lb	2,020 lb	4,058 "#	4,268 "#	3 pin OK

** Load defined as product weight per pair of beams Total: 330 lb 755 lb

Notes

Interior tunnel