

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Monday, September 23, 2024

Corrective Action Required:

2	Miscellaneous Correction	2134 SW Rutherford. Occupancy (2) -Sod, splash pads and sump pump extension is not installed -Sidewalk and driveway inspections need to pass
---	--------------------------	--

Comments: