



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114324, Building Permit - Commercial
Address: 188 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, October 13, 2011

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 101; 102; 103; 104 EXCEPT @ W.C.; 110; 111; 112;

Rated Assembly Inspection	John Borns	Partial	Thursday, October 13, 2011
----------------------------------	------------	---------	----------------------------

Partial Correction
1 MISC

OK TO TAPE, MUD, & FIRE-SEAL WHEN READY GWB INSTALLATION AT 1 HR FIRE-RATED WALLS @ FOLLOWING LOCATIONS: ALL EXCEPT 104

Comments: