CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768

Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection Robb Popp Partial Monday, September

23, 2024

Corrective Action Required:

1 STAIR TOWER 1 Stair in building F

-1st land 2nd ayer behind stringers only at all floors

Corrective Action Required:

2 STAIR TOWER 2 -Stair in building G

-1st and 2nd layer behind stringer only floors 1-2

Corrective Action Required:

3 STAIR TOWER 3 Stair 3 in Building J (J2)

Corrective Action Required:

4 STAIR TOWER 4 Stair 4 in Building J:

-1st and 2nd layer at stringer side only floors 1-3

-1st layer at 4th floor

Corrective Action Required:

5 STAIR TOWER 5

Corrective Action Required:

6 ELEVATOR 1 -1st and 2nd layer unit side behind trusses

Corrective Action Required:

7 ELEVATOR 2 Corrective Action Required:

8 FIRST FLOOR Building F:

-1st layer at truss space at firewall, stairwell and elevator for trusses at

corridor side only

Corrective Action Required:

9 SECOND FLOOR Building F:

-1st layer at truss space at firewall, stairwell and elevator for trusses at

corridor side only

Corrective Action Required:

10 THIRD FLOOR Building F:

-1st layer at truss space at firewall, stairwell and elevator for trusses at

corridor side only

-1st layer behind tubs and showers

Corrective Action Required:

11 FOURTH FLOOR Building F:

-1st layer at truss space at firewall, stairwell and elevator for trusses at

corridor side only -1st layer behind tubs

Comments: