

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241065
Address: 3730 SW KNOXVILLE CT, LEES SUMMIT, MO 640823728 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Not Ready	Tuesday, September 24, 2024

Corrective Action Required:

1	Miscellaneous Correction	3728 & 3730 SW Knoxville. Occupancy (4) 3730 First riser up from the main floor going upstairs is over the code allowance 7 3/4 inches high 3728 first riser up from main floor to upstairs is not to code (over the code allowed 7 3/4 inches) Exterior of both units Sod and splash pads are not installed Penetrations at gas line to siding needs to be sealed 3730 top hat of water meters in misaligned Remove mud from sidewalk and driveway Not all improvements were made before rescheduling inspection againNot ready
---	--------------------------	---

09/24/24. KBEARD time 8:50am

Comments: