

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241361
Address: 3228 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, September 24, 2024

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of sod -Guard rail at front stoop -address to be properly illuminated -secondary locking device at rear slider -label all outlets in unfinished space that are non-gfci (see sprinkler) -hand rail required at garage stairs
---	------	---

Comments: