CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20226232Address:120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Above Ceiling Inspection		Robb Popp	Failed	Tuesday, September 24, 2024
Correcti	ve Action Required:			
1	FIRST FLOOR	*****AREAS APPROVED TO COVER:		
		-Entry canopy ok to cover		
		Additon complete except as noted:		
		*AHU		
		-Address duct penetration/ complete firewall		
		**Existing side:		
		1E-314-seal penetra	tions	
		300C-seal penetrations and label firewall		
		1E-315-Label firewall		
		1E-313-seal penetra	tions and label firewall	
Correcti	ve Action Required:			
2	SECOND FLOOR	Above-ceiling OK below:		
		**Addition Complet	te	
Correcti	ve Action Required:			
3	THIRD FLOOR	*****AREAS APPRO	VED TO COVER:	
		Soffits at 3E-355, 346, 338, 241, 244, 306		
		UNITS 300A, 304-320, 360-367,335-349, 212, 213, 259-261, 246-258, 268-273,		
		214-219, 222, 224		
		9/24/24		

Seal penetrations and label smoke/fire walls at3E-332, 333, 104, Cor 300B, cor-300C, 205, 206, 327, 324,325, 322,323, 321, 263, 264, 265-REMOVE TILE FOR INSPECTION

Comments: