

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Failed	Tuesday, September 24, 2024

Corrective Action Required:

1	Misc	<b>**Pre final inspection for 2nd floor addition:</b> -GFCIs not working in all front bathrooms -322 GFCI not working -202 Tighten loose receptacle -204, 205, 210 not done <b>**SUBMIT FINAL 3rd PARTY INSPECTION REPORT</b>
---	------	--

**Comments:**