CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232768 Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Rated Assembly Inspection		Robb Popp	Partial	Tuesday, September 24, 2024
Corrective	e Action Required:			
1	STAIR TOWER 1	Stair in building F -1st land 2nd ayer behind	stringers only at all floors	
Corrective Action Required:				
2	STAIR TOWER 2	-Stair in building G -1st and 2nd layer behind	stringer only floors 1-2	
	e Action Required:			
3 STAIR TOWER 3 Corrective Action Required:		Stair 3 in Building J (J2)		
4	STAIR TOWER 4	Stair 4 in Building J: -1st and 2nd layer at strin -1st layer at 4th floor	ger side only floors 1-3	
Corrective Action Required:				
5	STAIR TOWER 5			
Corrective	e Action Required:			
6	ELEVATOR 1	 -1st and 2nd layer unit sid -1st layer at ceiling 	le behind trusses	
Corrective Action Required: 7 ELEVATOR 2 Corrective Action Required:				
8	FIRST FLOOR	Building F:		

		 -1st layer at truss space at firewall, stairwell and elevator for trusses at corridor side only 		
Corrective	e Action Required:			
9	SECOND FLOOR	Building F: -1st layer at truss space at firewall, stairwell and elevator for trusses at corridor side only		
Corrective Action Required:				
10	THIRD FLOOR	Building F:		
		-1st layer at truss space at firewall, stairwell and elevator for trusses at		
		corridor side only		
		-1st and 2nd layer behind tubs and showers		
Corrective	e Action Required:			
11	FOURTH FLOOR	Building F:		
		-1st layer at truss space at firewall, stairwell and elevator for trusses at corridor side only		
		-1st and 2nd layer behind tubs		

Comments: