

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242080

Address: 3725 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3723 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Wednesday, September 25, 2024

Informational:

1 Misc

9-20-24 Dustin A, Dw is formed and compacted. Depth is in compliance . Will need to maintain ada compliance . Approved to pour.

9-25-24 Dustin A, DW is poured to city specs and slopes are in compliance.
Passed

Comments: