

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242763

Address: 3713 SW KNOXVILLE CT, LEES SUMMIT, MO 640823711 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|----------------------------------|
| Underslab Plumbing Inspection - Residential | Kyle Beard | Passed | Wednesday, September 25, 2024 |

Comments: