## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRCOM20226232Address:120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Above Ceiling Inspection		Robb Popp	Failed	Wednesday, September 25, 2024	
Correctiv	ve Action Required:				
1	FIRST FLOOR	*****AREAS APPROVED TO COVER:			
		-Entry canopy ok to cover			
		Additon complete except as noted:			
		*AHU			
		-Address duct penetration/ complete firewall			
	**Existing side:				
		1E-314-seal penetrations			
		300C-seal penetrations and label firewall			
		1E-315-Label firewall			
		1E-313-seal penetra	tions and label firewall		
Correctiv	ve Action Required:				
2	SECOND FLOOR	Above-ceiling OK be	Above-ceiling OK below:		
		**Addition Complet	e		
Correctiv	ve Action Required:				
3	THIRD FLOOR	*****AREAS APPRO	*****AREAS APPROVED TO COVER:		
		Soffits at 3E-355, 346, 338, 241, 244, 306			
		UNITS 300A, 304-320, 360-367,335-349, 212, 213, 259-261, 246-258, 268-273,			
		214-219, 222, 224			
		9/24/24			

Seal penetrations and label smoke/fire walls at3E-332, 333, 104, Cor 300B, cor-300C, 205, 206, 327, 324,325, 322,323, 321, 263, 264, 265-REMOVE TILE FOR INSPECTION

Comments: