## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20231351 Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Water Line - Construction Inspection		Inspector: Bobby Richest	Outcome: Partial	Date: Wednesday, September 25, 2024
1 1	Vlisc	9-18-24 BR Contractor (Selby Excavation) installed 250' of 8" water main on line G from Sta. 4+55 - Sta. 2+00. At Sta. 4+20 contractor installed 11.25' bend to get water main back on center line do to when 8" gate was installed it was 3' off center line.		
		9-19-24 BR Contractor (Selby Excavation) installed 300' of 8'' water main on line G from Sta. 2+00 - Sta. 0+00. With 100' on water line A from Sta. 2+20 - 3+00.		
			Sta. 9+00. 2nd crew ins	alled 500' of 8'' water main on talled 200' of 8'' water main on
Comments	:			