

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20241951

Address: 3191 NW PARAGON PKWY, LEES SUMMIT, MO 64081  
3150 NW PARAGON PKWY, LEES SUMMIT,  
MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection</b>	John Jackson	Passed	Wednesday, September 25, 2024

Informational:

1 Misc

09/18/24 Wednesday JMJ (Rodriguez Construction)

Waiting for the last sample to pass bacterial sample test to notify Water.

09/25/24 Wednesday JMJ ( Pro-Design Construction)

Contractor installed approximately installed a 6"X4" tap for irrigation line 60' of 4" with a straddle block. Meter was installed on the Northeast side of building. Contractor also completed Fireline hydrostatic @200psi same corner of building.

**Comments:**