

***David P. Ainsworth, P.E.***  
***1200 NW Hearnese Ave Blue Springs, MO***  
***Cell Phone: 816-682-2093***  
***Email: dainsworth@chelepis.com***

September 25, 2024

Mr. Duane Hatton  
Garys Foundation  
1207 S Powell Rd, Independence, MO 64057

Re: Property @  
1105 SW Fiord  
Lee's Summit, MO  
Trumark Permit 2024-4628  
Foundation Footing Inspection

Dear Mr. Hatton:

On September 25, 2024, I inspected the footing that was prepared for concrete placement at the above referenced property.


Footing forms were properly aligned and braced.


Reinforcing steel was properly installed and supported.


The footings are approved for concrete placement.

Deck post piers were also inspected and are approved.

Cordially,

  
David P. Ainsworth



  
9-25-24