

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242210
Address: 1020 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Robb Popp	Failed	Thursday, September 26, 2024

Informational:

1	Misc	5' welded roof transition piece approved on ground
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	Correct (3) pinholes in welded connection to captive air system
---	-----------------------------	---

Comments: