

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240375
Address: 102 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Robb Popp	Failed	Thursday, September 26, 2024

Corrective Action Required:
1 Misc Install combo smoke/CO detector outside of bedroom
Corrective Action Required:
2 Misc 9/26/24 9:44 am
-Called and left message, knocked on door no answer

Comments: