

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243996
Address: 3212 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, September 26, 2024

Informational:	
1 Misc	- OUTSIDE NAIL PATTERN OK TO COVER - NO STRAPS - ANCHOR BOLTS TO BE IN MIDDLE THIRD OF PLATE

Comments: