

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20235554  
Address: 816 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
818 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
814 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Thursday, September 26, 2024

Corrective Action Required:

1	Misc	Unit 814: -Complete deck. Install approved post caps at deck beam connections to posts; install hanger for upper landing cross joist connection to double joist; return bottom end of handrail to newel post -Provide sewer tracer wire port at grade  816: -Provide sewer tracer wire port at grade -Complete deck -Provide verification that the master bathroom shower door is safety tempered glazing -Install box extension and close off box inside master bathroom cabinet -Where's the gfci for the master bathroom sink receptacle? -Move the dryer&washer away from wall so I can test the receptacle
---	------	---

Corrective Action Required:

2	Misc	UNIT 818 - PROVIDE THROUGH BOLTS AT POST TO BEAM CONNECTIONS ON DECK - ADD SUPPORT FOR DECK STAIRS - LOWER WATER METER IN PIT TO 14-18" FROM LID -Provide sewer tracer wire port at grade
---	------	---

**\*\*TCO approved for unit 814 and 818 only**

**Comments:**