CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20226232Address:120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Above Ceiling Inspection		Robb Popp	Partial	Thursday, September 26, 2024	
Correc	ctive Action Required:				
1	FIRST FLOOR				
		-Entry canopy ok to cover			
			dditon complete except as noted:		
		*AHU	*AHU		
		-Address duct penetration/ complete firewall			
		**Existing side:			
		1E-314-seal penetrations			
		300C-seal penetrations and label firewall			
		1E-315-Label firewall			
		1E-313-seal penetrations and label firewall			
Correc	ctive Action Required:				
2	SECOND FLOOR	Above-ceiling OK b	elow:		
		**Addition Comple	te		
Correc	ctive Action Required:				
3	THIRD FLOOR	*****AREAS APPRO	VED TO COVER:		
		Soffits at 3E-355, 346, 338, 241, 244, 306			
				3, 259-261, 246-258, 268-273,	
		214-219, 222, 224			

Seal penetrations and label smoke/fire walls at3E-323 and 101b

Comments: