



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113001, Building Permit - Commercial
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mark Harding	Failed	Friday, October 14, 2011

Corrective Action Required
1 MISC

1. INSTALL GRAB BARS IN RESTROOMS PER CODE

11. PROVIDE ROOF ACCESS FOR INSPECTION.

16. PAINT ROOFTOP GAS PIPING

PROVIDE GAS TEST AFTER VALVE INSTALLED UP STREAM OF UNION ABOVE CEILING AT SOUTH WEST ROOM.

SCHEDULE GAS PIPING INSPECTION, SCHEDULE FINAL OCCUPANCY INSPECTION

Above Ceiling Inspection	Mark Harding	Failed	Friday, October 14, 2011
---------------------------------	--------------	--------	--------------------------

Corrective Action Required
1 MISC

DO NOT COVER SOUTH WEST ROOM / PENDING GAS LINE APPROVAL AND FIRE PENETRATION.

Comments:

