

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241112
Address: 3731 SW KNOXVILLE CT, LEES SUMMIT, MO 640823729 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Thursday, September 26, 2024

Corrective Action Required:

2	Miscellaneous Correction	3729 and 3731 SW Knoxville. Occupancy (2)
---	--------------------------	---

Both units
sod and splash pads needs to be installed
Seal all exterior penetrations
As graded plot plan is not uploaded
Check back decks for missing nails at hangers and missing bracket at ledger to rim joist

Both units passed for TCO only

Comments: