

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Partial	Thursday, September 26, 2024

Corrective Action Required:

1	Misc	<p><b>**Pre final walkthrough for 2nd floor addition: partial final</b></p> <ul style="list-style-type: none"><li>-GFCIs not working in all front bathrooms</li><li>-322 GFCI not working</li><li>-202 Tighten loose receptacle</li><li>-204, 205, 210 not done</li></ul> <p><b>**SUBMIT FINAL 3rd PARTY INSPECTION REPORT</b></p> <p><b>**Pre final walkthrough for 3rd floor addition Women's health suite: partial final</b></p> <ul style="list-style-type: none"><li>335-Toilet to be 16-18" from side wall to centerline, GFCI not working</li><li>302-GFCI not working</li><li>303-GFCI not working, update plan to show no ADA compliance for clearance in front of WC</li><li>324-GFCI not working</li><li>-Complete above ceiling inspection at 323, 101B and lobby</li><li>-Complete elevator</li><li>-Complete alarm inspection for LSFD</li><li>-Submit final 3rd party inspection report as previously requested</li><li>-Install drinking fountain</li><li>-Submit phasing plan as previously requested</li><li>-Complete all sinks and missing fixtures</li></ul>
---	------	---

**Comments:**